

(An ISO 3297: 2007 Certified Organization)

Vol. 3, Issue 6, June 2014

Modelling and Simulation of Interacting Conical Tank Systems

S.Vadivazhagi¹, Dr.N.Jaya²

Assistant Professor, Department of ECE, MRK Institute of Technology, Kattumannarkoil, Tamilnadu, India¹

Associate Professor, Department of E&I, Annamalai University, Chidambaram, Tamilnadu, India²

ABSTRACT: This paper describes the controller design of non linear system. The Non linear system taken up for the study is the Interacting Conical Tank Systems. In this paper, design of controllers based on Skogestad tuning is determined. For each stable operating region, a first order process model is identified using Process reaction curve method. The control is done and the responses for different operating regions are taken. Simulation is made by the MATLAB software.

KEYWORDS: Non Linear System, Mathematical Modelling, Interacting Conical Systems, Skogestad PI controller.

I. INTRODUCTION

In most of the industries chemical process present many challenging problems due to their nonlinear dynamic behaviour.Because of inherent non linearity, most of the chemical process industries are in need of traditional control techniques.One such non linear process taken up for study is Interacting Conical systems[1].

Conical tanks are best suited for food process industries, concrete mixing industries, hydrometallurgical industries and waste water treatment industries. Its shape contributes to better drainage of solid mixtures, slurries and viscous liquids. To achieve a satisfactory performance using conical tanks, its controller design becomes a challenging task because of its non - linearity. This non - linearity arises due to its shape. It is broad at the end and becomes narrow in the lower end[10]. The primary task of a controller is to maintain the process at the desired set point and to achieve optimum performance when facing various types of disturbances .

Conventional controllers are widely used in industries since they are simple, robust and familiar to the field operator. Practical systems are not precisely linear but may be represented as linearized models around a nominal operating point[4].

The work in this paper is divided in two stages. 1) Mathematical Modelling 2) Skogestad controller Implementation. A Mathematical model is developed for Two Tank Conical Interacting system using the Mass Balance Equation. The operating parameters of the process is given in a table from which the Open loop response of the process is obtained. Piecewise Linearization is carried out. The controller tuned using Skogestad method named after the originator is based on the direct method. The objective of the paper is to show that by employing the proposed tuning of PI controllers, an optimization can be achieved[2].

The Proportional Integral(PI) and Proportional-Integral-Derivative(PID) controllers are widely used in many industrial control systems for several decades.S.Nithya et al.[1] discussed about the control issues associated with the non linear systems in real time using cost effective data acquisition system.The limitations of a PI controller for a first order non linear process with dead time was discussed by R.Anandanatarajan et al.[2].D.Dineshkumar et al.[4]. implemented Skogestad PID controller for Interacting Spherical Tank System.Simulation studies were carried out for this non linear process.Sigurd Skogestad[5] proposed the best simple tuning rules in the world.The analytical tuning rules are as simple as possible and still result in a good closed-loop behaviour.A Neuro based model reference Adaptive control of a conical tank level was proposed by N.S.Bhuvaneswari et al.[6].

Paper is organized as follows. Section II describes the Mathematical Modelling of Two Tank Conical Interacting Systems and its operating parameters. Piecewise linearization is carried out around four different operating regions . The implementation of Skogestad PI controller is discussed in Section III. Section IV presents experimental results showing four different simulations for four regions. Finally, Section V presents Conclusion.



(An ISO 3297: 2007 Certified Organization)

Vol. 3, Issue 6, June 2014

II. MATHEMATICAL MODELLING OF TWO TANK CONICAL INTERACTING SYSTEM

The two tank conical interacting system consists of two identical conical tanks (Tank 1 and Tank 2), two identical pumps that deliver the liquid flows F_{in1} and F_{in2} to Tank 1 and Tank 2 through the two control values C_{V1} and C_{V2} respectively. These two tanks are interconnected at the bottom through a manually controlled value, MV_{12} with a value coefficient β_{12} . F_{out1} and $F_{out 2}$ are the two output flows from Tank 1 and Tank 2 through manual control values M_{V1} and M_{V2} with value coefficients β_1 and β_2 respectively[3].




Fig. 1 Schematic diagram of Two tank Conical Interacting System

Parameter	Description	Value
R	Top radius of conical tank	19.25cm
Н	Maximum height of Tank1&Tank2	73cm
Fin1 & Fin2	Maximum inflow to Tank1&Tank2	252cm ³ /sec
β_1	Valve coefficient of MV ₁	$35 \text{ cm}^2/\text{sec}$
β ₁₂	Valve coefficient of MV ₁₂	$78.28 \text{ cm}^2/\text{sec}$
β_2	Valve coefficient of MV ₂	$19.69 \text{ cm}^2/\text{secs}$

Table. 1 Operating Parameters of Two tank Conical Interacting System

The non linear equations describing the open loop dynamics of the Two Tank Conical Interacting Systems is derived using the Mass balance equation and Energy balance equation principle[9]. The Mathematical model of The mathematical model of two tank conical interacting system is given by [6]:

$$\frac{dh_{1}}{dt} = \left[\frac{F_{in1} - h_{1}\frac{dA(h_{1})}{dt} - \beta_{1}\sqrt{h_{1}} - sign(h_{1} - h_{2})\beta_{12}\sqrt{|h_{1} - h_{2}|}}{\frac{1}{3}\pi R^{2}\frac{h_{1}^{2}}{H^{2}}}\right]$$
(1)
$$\frac{dh_{2}}{dt} = \left[\frac{F_{in2} - \beta_{2}\sqrt{h_{2}} + sign(h_{1} - h_{2})\beta_{12}\sqrt{|h_{1} - h_{2}|} - h_{2}d\frac{A(h_{2})}{dt}}{\frac{1}{3}\pi R^{2}\frac{h_{2}^{2}}{H^{2}}}\right]$$
(2)

Copyright to IJIRSET

www.ijirset.com



(An ISO 3297: 2007 Certified Organization)

Vol. 3, Issue 6, June 2014

Where




Fig. 2 Open loop response of h_1 and h_2 .

The process considered here has non linear characteristics and can be represented as piecewise linearized regions around four operating regions.

Region	Flow	Height h1	Height h2
	(cm^3/s)	(cms)	(cms)
Ι	0-66	1.462	1.374
II	66-120	4.49	4.19
III	120-186	9.913	8.447
IV	186-252	13.97	12.56

Table. 2 Various regions of response

III. IMPLEMENTATION OF SKOGESTAD PI CONTROLLER

Transfer function for every region is obtained by substituting the values of time constant and gain using Process reaction curve method[7].Transfer functions for different regions are represented in Table II. PI controller is designed based on Skogestad method [5].

Region	Inflow	Height h ₂	Steady	Time	Transfer
	(cm^3/s)	(cms)	State	constant	Function
			Gain	(secs)	
Ι	0-66	1.374	0.0208	0.002	0.0208
					0.002s+1
II	66-120	4.19	0.0349	0.03	0.0349
					0.03s+1
III	120-186	8.447	0.0454	0.146	0.0454
					0.146s+1
IV	186-252	12.56	0.0498	0.338	0.0498
					0.338s+1

Table. 3 Model Parameters of Two tank Conical Interacting System



(An ISO 3297: 2007 Certified Organization)

Vol. 3, Issue 6, June 2014

PI controller is designed for all the four regions based on Skogestad method.Figure 3 represents the simulink diagram of PI controller for region I using Matlab[4] and it also depicts the blocks used to find error indices.Similarly the Process is simulated for different regions and the responses obtained with and without disturbances are discussed in section IV.




Fig. 3 Simulink diagram for region1

Region	Inflow	Height h ₂	K _P	KI
	(cm^3/s)	(cms)		
Ι	0-66	1.374	50	50/0.002
II	66-120	4.19	30	30/0.03
III	120-186	8.447	23.17	23.17/0.146
IV	186-252	12.56	21.25	21.25/0.338

Table. 4 Controller Parameters for four regions in Two tank Conical Interacting System

IV. SIMULATION RESULTS

The simulation is carried out using MATLAB.First the non linear response of Two Tank Conical Interacting Systems is linearised into four regions and the optimum PI controller parameters for these four regions is estimated. Figures 4,5,6 and 7 shows the controller response for regions 1,2,3 and 4 with and without disturbance.




Fig. 4 Controller response for region 1 (a) Without disturbance (b) With disturbance

Figure 4. shows the controller response for region 1 (0-66 cm^3/s). A set point of 1 is given. The response as shown in Figure 4(a) clearly indicates how the controller takes the action for the given set point. Also the response shown by Figure 4(b) confirms the controller action even in the presence of disturbance so as to reach the desired set point.



(An ISO 3297: 2007 Certified Organization)

Vol. 3, Issue 6, June 2014




Fig. 5 Controller response for region 2 (c) Without disturbance (d) With disturbance

Figure 5. shows the controller response for region 2 (66-120 cm³/s). A set point of 1 is given. The response as shown in Figure 5(c) clearly indicates how the controller takes the action for the given set point. Also the response shown by Figure 5(d) confirms the controller action even in the presence of disturbance so as to reach the desired set point.




Fig. 6 Controller response for region 3 (e) Without disturbance (f) With disturbance

Figure 6. shows the controller response for region 3 (120-186 cm³/s). A set point of 1 is given. The response as shown in Figure 6(e) clearly indicates how the controller takes the action for the given set point. Also the response shown by Figure 6(f) confirms the controller action even in the presence of disturbance so as to reach the desired set point.




Fig. 7 Controller response for region 4 (g) Without disturbance (h) With disturbance

Figure 7. shows the controller response for region 4 (186-252 cm³/s). A set point of 1 is given. The response as shown in Figure 7(g) clearly indicates how the controller takes the action for the given set point. Also the response shown by Figure 7(h) confirms the controller action even in the presence of disturbance so as to reach the desired set point.



(An ISO 3297: 2007 Certified Organization)

Vol. 3, Issue 6, June 2014

Skogesad PI controller is implemented on Conical Interacting systems through simulation and the respective servo and regulatory responses were obtained. From the figures it can be inferred that the designed Skogestad PI controller takes the controller action at every region for the given Setpoint even in the presence of disturbance.

V. CONCLUSION

In this paper, Skogestad PI controller is designed for a Two tank Conical Interacting System. The Simulation results confirm that the controller designed gives satisfactory response for a given set point .Also the controller effectively rejects the disturbance and brings back the output to the desired set point.

REFERENCES

- [1] Nithya.S,Abhay Singh.G,Radhakrishnan.T.K,Balasubramanian.T and Anantharaman.N, "Design of intelligent controller for non-linear process",Asian Journal of applied Science, Vol. 1, pp.33-45,2008.
- [2] Anandanatarajan.R ,Chidambaram.M and Jayasingh.T,"Limitations of a PI controller for a first order non-linear process with dead time",ISA Transactions,Vol. 45,pp. 185-200,2006.
- [3] Ravi.V.R and Thyagarajan.T, "A decentralized PID controller for interacting non linear systems", Proceedings of Emerging trends in Electrical and Computer Technology, pp. 297-302, 2008.
- [4] Dinesh Kumar.D,Dinesh.C and Gautham.S, "Design and Implementation of Skogestad PID Controller for Interacting Spherical Tank System",International journal of Advanced Electrical and Electronics Engineering, Vol. 2, pp. 117-120, 2013.
- [5] Sigurd Skogestad, "Probably the best simple PID tuning rules in the world", Journal of Process Control, pp. 1-27,2001.
- [6] Bhuvaneswari.N.S.,Uma.G and RangaswamyT.R, "Neuro based Model Reference Adaptive control of a conical tank level process",Control and Intelligent Systems,Vol.36,pp. 1-9,2008.
- [7] Wayne Bequette.B, "Process control Modeling, Design and simulation", Prentice Hall, USA, 2003.
- [8] Deshpande.B, "Multivariable Process Control", Instrument society of America, 1989.
- [9] George Stephanapoulos, "Chemical Process control", Prentice Hall of India, New Delhi, 1990.
- [10] Chidambaram.M, "Non linear Process control", New Age International Publishers Limited, Wiley Eastern Limited, 1995.

BIOGRAPHY



S.Vadivazhagi is presently working as an Assistant Professor in the Department of ECE at MRK Institute of Technology,Kattumannarkoil,Tamilnadu,India. She received her B.E degree in 2001 and M.E degree in 2006 in the Department of Instrumentation Engineering from Annamalai University,Chidambaram,Currently she is persuing her Ph.D degree in the area of Process Control at Annamalai University.



Dr.N.Jaya is presently working as an Associate Professor in the Department of Instrumentation Engineering at Annamalai University, Chidambaram, India. She received her BE, ME and PhD degrees from Annamalai University, India in 1996,1998 and 2010 respectively. Her main research includes process control, fuzzy logic control, control systems and adaptive control.



(An ISO 3297: 2007 Certified Organization)

Vol. 3, Issue 6, June 2014