

(An ISO 3297: 2007 Certified Organization) Vol. 4, Issue 1, January 2015

Efficacy of Established Standard Deviation on M30 Grade Concrete

S. Mishra¹, Doyol Kenna-o², Lagun Sonam², Pynksan Pamtheid² and Rei Taram²

¹ Associate Professor, Dept. of Civil Engineering, North Eastern Regional Institute of Science and

Technology(NERIST), Nirjuli, Itanagar, Arunachal Pradesh, India

² B. Tech. students, Dept. of Civil Engineering, North Eastern Regional Institute of Science and Technology(NERIST),

Nirjuli, Itanagar, Arunachal Pradesh, India

ABSTRACT: Concrete is a very common construction material and only design mix concrete is permitted for M25 and higher grade. For this study, M30 grade concrete mix was designed by using 53 grade ordinary Portland cement $(OPC)^1$, 20 mm angular graded aggregate of nominal size and zone III river sand². Based on guidelines of IS 456 : 2000 and IS 10262 : 2009, assumed standard deviation (SD) was used for calculating target mean. From final mix concrete, samples were tested and result of 32 samples were analysed and established SD was calculated. Value of established SD was found 2.43 N/mm² against the assumed standard deviation 5.0 N/mm². Corresponding to the established SD, water cement ratio was 0.4725 and cement content in the proportioned mix was reduced by 31.98 kg/m³ of concrete.

KEYWORDS: Concrete, M30 grade concrete, Cement content, Standard deviation,

I. INTRODUCTION

Concrete is used in various construction activities and its basic ingredients are cement, fine aggregate (sand), coarse aggregate, water and admixtures, if any. By using cement and locally available ingredients, oncrete is produced at construction site or at suitable industrial plants. The ingredients are mixed in known proportion same is finalised by two ways: based on tradition ratio and as per design of concrete mix. Design mix concrete proportion is finalised by codal provisions, considering properties of ingredients, quality control of concrete production and other specific requirements. For design mix, target strength is estimated for probability factor corresponding to 5% failure of test results and assumed standard deviation (SD) for particular grade of concrete^{3,4}. For the same target strength, concrete mix is designed and minimum 30 samples from fresh concrete are taken and cubes are made, cured and tested at 28 days⁵. Standard deviation is established from the test results samples and this is brought up-to-date after every change of mix proportioning, materials used and changes in concrete production system. Standard deviation is established by using even using less than 30 sample results and in such cases SD should be multiplied by factors 1.16, 1.08, 1.03 and 1.0 for 15, 20, 25 and 30 or more samples respectively⁶. Marcia (1997) discussed optimisation of concrete mixtures by statistical methods and found the residual standard deviation 3.39 N/mm² for 36 samples⁷. Concrete required for a plain concrete pavement constructed in North Dakota for specified compressive of 35 MPa at 28 days, the standard deviation of 2.0 N/mm² is reported for particular producer⁸. Malagavelli et.al (2012) studied strength of concrete by using fours different types of super plasticizers and found established SD within the range of 0.73 to 3.41 N/mm² for concrete samples with plasticisers and 1.33 N/mm² for concrete samples without super plasticiser⁹.

In absence of established standard deviation, assumed standard deviation given in Table 8 of IS 456 : 2009 is used for target strength calculation. The values of assumed standard deviations are 3.5 N/mm^2 for M10 and M15 grade concrete, 4.0 N/mm² for M20 and M25 and 5.0 N/mm² for M30 and higher grade concrete. In absence of appropriate quality control measures, the values of assumed SD are increased by 1 N/mm^2 and these SD values are used for designing up



(An ISO 3297: 2007 Certified Organization)

Vol. 4, Issue 1, January 2015

to M55 grade concrete mixes. Based on the adequate past records for a similar grade of concrete, justifying the designer, an appropriate value of SD, different than that of given in Table 8, is also permissible.

For the given set of ingredients in concrete mixes, cement content increases in higher grade of concrete. Due to increase in heat of hydration, increased risk of cracking due to drying and shrinkage in thin sections, early thermal cracking and increased risk of damage due to alkali silica reactions, maximum use of ordinary Portland cement (OPC) in concrete is limited to 450 kg/m³ (sub section 8.2.4.2 IS 456 : 2000). Accordingly, in higher strength concrete, cement content is to be maintained within permissible limit by adopting appropriate measures without compromising strength and durability parameters. Initially for designing concrete mix of a given characteristic strength, target strength is determined adopting assumed standard deviation. By observing good quality control measures for producing homogeneous concrete mix, established standard has lower value. Based on established SD values, target strength reduces and in turn resulting increase in w/c and decrease in cement content for the same grade of concrete.

II. RELATED WORK

For M30 grade concrete, 53 grade ordinary Portland cement (OPC), 20 mm graded angular coarse aggregate of nominal size and river sand confirming to zone III were used. Specific gravity of coarse and fine aggregate was 2.78 and 2.706 respectively. Target strength calculated using assumed value of standard deviation with uncontrolled site condition was 39.90 N/mm². For 25 – 50 slump value and severe exposure condition, proportion for trial mix I was calculated as per IS 10262 : 2009 and given as Appendix . Fresh concrete was made from the same proportion (Table -I) and slump value was found 30 mm. The mix proportion was designated as trial mix II and cubes were casted. Varying w/c \pm 10%, proportions for trail mixes III and IV were calculated and cubes were casted from both mixes. After 28 days under water curing, cube samples from all trial mixes were tested and results were checked for acceptance criteria. Mean values for all three sets of samples were calculated and using these values graph was plotted. Corresponding to target strength, w/c for final mix was found from the same plot (Figure -1) and using w/c as 0.473, final mix proportion was calculated. From final mix concrete proportion 33 cube samples were tested and validity of tests results, as per clause 15.4 of IS 456 : 2000, was checked. All tests results were valid and given in Table -2. Valid tests results of 32 samples were arranged in 8 groups of four non overlapping consecutive sample sets and results of all groups were checked for acceptance criteria based on provisions of table – 11, section 16.1 and 16.3 of IS 456 : 2000. Test results of all samples were satisfying the acceptance criteria for mean of the group of four cubes and individual strength requirement of each cube. From all 32 acceptable results, mean strength and established standard deviation were calculated (Table - 4). Using established SD, target strength was recalculated and for the same target strength w/c was calculated and concrete mix proportion was calculated again. Cement content for the same mix was found 393.63 kg/m³ of concrete.

III. RESULT AND DISCUSSION

Average compressive strength of trail mix II, III and IV samples was 37.25 N/mm², 30.25 N/mm² and 43.50 N/mm² respectively. For assumed SD, target strength was 39.9 N/mm² and the value of water cement ratio (0.437) for final mix was obtained from figure – 1. Cement content of final mix was 425.63 N/mm². Compressive strength results of 33 samples were ranging between 32.89 N/mm² to 42.22 N/mm² (Figure – 2). Maximum and minimum values of mean strength of three cube sets were 35.407 N/mm² and 37.963 N/mm² from sixth and eighth set respectively. Upper and lower limit for validity for the same sets were 40.72 N/mm² and 30.10 N/mm²; and 43.66 N/mm² and 32.27 N/mm² respectively. For acceptance criteria, highest and lowest values for four consecutive non overlapping samples were 35.47 N/mm² for third and sixth group respectively. Minimum strength for a group of four consecutive non overlapping and individual samples were 34.13 N/mm² and 26 N/mm² respectively. Mean value and established standard deviation of 32 accepted sample results were 36.67 N/mm² and 2.43 N/mm² respectively. Using established SD, target strength reduced from 39.90 N/mm² to 35.64 N/mm². For the same value of target strength, cement content was 393.65 kg/m³ of concrete 8.12% saving in cement content.



(An ISO 3297: 2007 Certified Organization)

Vol. 4, Issue 1, January 2015

For optimal use of resources, final mix design proportion should be recalculated by using established standard deviation obtained from test results of samples from initial works.

REFERENCES

- IS 12269 Specification for 53 Grade Ordinary Portland Cement, BIS, New Delhi 110002, 987 (Reaffirmed 1999) [1]
- IS 383 Specification for Coarse and Fine Aggregates from Natural Sources for concrete, BIS, New Delhi 110002, 1970 (Reaffirmed 2002) [2]
- IS 456 Plain and Reinforced Concrete Code of Practice (Fourth Revision), BIS, New Delhi 110002, 2000 [3]
- IS 10262 Recommended Guidelines for Mix Design, BIS, New Delhi 110002, 2009. [4]
- [5] IS 516 Methods of Tests for Strength of Concrete, BIS, New Delhi – 110002, 1959 (Reaffirmed 1999)
- ACI 318-95 / 318R-95 : 1995 Building Code Requirements for Structural Concrete and Commentary, American Concrete Institute, [6] Farmington Hills, MI 4833, pp-44, 1995. Marcia J. Samon, (1997), "Concrete Mixture Optimisation Using Statistical Mixture design Methods", International Symposium on High
- [7] Performance Concrete, New Orleans, Louisiana, October 20-22, 1997, pp 230-244.
- [8] Portland Cement Association, "Design and Control of Concrete Mixtures(13th ed) (EB-001)", Chapter 9, pp166, 2012)
- Malagavelli V. and Paturu N. R. "Strength and Workability Characteristics of Concrete by Using Different Super-plasticizers", International [9] Journal of Materials Engineering 2012, 2(1): 7-11

APPENDIX

Concrete Mix Design for M₃₀ Grade Concrete Stipulations for proportioning and test data for materials:

a)	Grade designation	:	M30
b)	Type of cement	:	OPC 53Grade
c)	Maximum nominal size of aggregate	:	20 mm
d)	Minimum cement content	:	320 kg/m^3
e)	Maximum water cement ratio	:	0.45
f)	Workability	:	25 - 50 mm (slump)
g)	Exposure condition	:	severe
h)	Degree of supervision	:	partially uncontrol
i)	Type of aggregate	:	crushed angular aggregate
j)	Maximum cement content	:	450 kg/m^3
k)	Specific gravity of coarse aggregate	:	2.78
1)	Specific gravity of fine aggregate	:	2.701
m)	Specific gravity of cement	:	3.15

Target strength (f_t) for mix proportioning

$f_t = f_{ck} +$	1.65 * s
	f_{ck} = characteristic compressive strength at 28 days, and
	s = standard deviation.
Target mean strength	$= 30 + 1.65 \times (5+1)$
= 3	89.90 N/mm ²

Selection of water-cement ratio and water content

Value of maximum water-cement, 0.45 was selected for mix proportioning. For 20 mm graded angular aggregate of nominal size and 25 - 50 mm slump value, water content was 186 $1/m^3$ of concete.

Calculation of cement content and checking for minimum cement content



(An ISO 3297: 2007 Certified Organization)

Vol. 4, Issue 1, January 2015

For selected water cement ratio 0.45 and water content 186.0 $1/m^3$ of concrete, cement content was calculated as = 186/0.45 = 413.33 kg / m³.

Cement content as above was higher than minimum cement content for severe exposure conditions within permissible range.

Proportion of volume of coarse aggregate and fine aggregate content

From IS 10262 : 2009, table no. 3, pg. 3, volume of coarse aggregate in all aggregate fraction corresponding to 20 mm size aggregate and fine aggregate (zone III) for water cement ratio 0.50 was found 0.64. For the selected case water-cement ratio as 0.45 adjustment was incorporated at the rate of -/+ 0.01 for every +/- 0.05 change in water cement ratio. Adjusted proportion of volume of coarse aggregate for water-cement ratio of 0.45 was 0.65 and volume of fine aggregate was found as 0.35.

Mix Calculation

Volume of concrete in one cu m of concrete

 $=\frac{mass \ of cement}{specific gravity of cement} \times \frac{1}{1000} = \frac{413.33}{3.15} \times \frac{1}{1000} = 0.131 \text{ m}^3$ Volume of water $=\frac{mass \ of water}{specific gravity of water} \times \frac{1}{1000} = 186/1 \times 1/1000 = 0.186 \text{ m}^3$

Volume of all in aggregate (e) = 1 – (volume of cement+vol. of water) = 1-(0.1312+0.186) = $0.683m^3$ Mass of coarse aggregate = e ×volume of coarse aggregate × sp.gr of coarse agg.×1000 = $0.683\times0.65\times2.74\times1000 = 1216.42 \text{ kg/m}^3$. Mass of fine aggregate = e × volume of fine aggregate × sp.gr. of fine agg. × 1000 = $0.683\times0.35\times2.706\times1000 = 646.86 \text{ kg/m}^3$.

Trial mixes	Ingredients	Water	Cement	Sand	СА
TM II	kg/m ³	186.00	413.33	646.66	1216.04
1 1/1 11	Proportion	0.450	1.000	1.565	2.942
TM III	kg/m3	186.00	375.76	674.88	1220.15
1 1/1 111	Proportion	0.495	1.000	1.796	3.247
TM IV	kg/m3	186.00	459.26	616.58	1206.55
I IVI I V	Proportion	0.405	1.000	1.343	2.627
Final mix	kg/m3	186.00	425.63	638.19	1213.92
	Proportion	0.437	1.000	1.499	2.852
Final mix with	kg/m3	186.00	393.65	660.97	1218.67
established SD	Proportion	0.473	1.000	1.679	3.096



(An ISO 3297: 2007 Certified Organization)

Vol. 4, Issue 1, January 2015

Specimen No.	Failure Load	Wear of the Kange of test festil				
110.		_	samples	(±15%)N/mm ²	Remarks for
	(kN)	(N/mm ²)	N/mm ²	Maximum	Minimum	test result
1	860	38.22	-			
2	740	32.89	37.33	42.93	31.73	
3	920	40.89				
4	800	35.56				
5		810 36.00 36.30 41.74		41.74	30.85	
6	840	37.33				
7	830	36.89				
8	840	37.33	36.00	41.40	30.60	
9	752	33.78				
10	820	36.44				1
11	800	35.56	36.15	41.57	30.72	
12	820	36.44				Valid
13	760	34.78				
14	910	38.44	36.85	42.38	31.32	
15	840	37.33				
16	750	33.33			30.10	
17	840	37.33	35.41	40.72		
18	800	35.56				
19	755	34.33				1
20	800	35.56	37.37	42.98	.98 31.76	
21	950	42.22				
22	905	39.56				
23	790	35.11	37.96	43.66	6 32.27	
24	900	39.22				
25	850	37.78				
26	840	36.78	36.30	41.74	30.85	
27	755	34.33				
28	820	36.44				
29	890	38.78	36.67	42.17	2.17 31.17	
30	840	34.78				
31	755	36.00				
32	820	37.33	36.52	42.00	31.04	
33	815	36.22	1			

Table - 2 Validity of test results of samples (clause 15.5, IS 456 : 2000)



(An ISO 3297: 2007 Certified Organization)

Vol. 4, Issue 1, January 2015

	Failure	Compressive	Mean of the group				
no.	11			Acceptance criter	Individual	Remark	
	load	strength	of 4 non-overlapping	of mean strength of four non		test result,	
			consecutive four	overlapping cor		$(f_{ck} - 4)$	
			sample result	samples (N/mm ²)		(N/mm^2)	
	(kN)	(N/mm^2)	(N/mm^2)	Maximum	Minimum		
				(f _{ck} +0.825 * SD)	$(f_{ck} + 4)$		
1	860	38.22					
2	740	32.89	36.89	34.125	34	26	ОК
3	920	40.89	50.07	54.125	54	20	ÖK
4	800	35.56					
5	810	36.00					
6	840	37.33	36.89	34.125	34	26	OK
7	830	36.89	50.07	54.125	54	20	OK
8	840	37.33					
9	752	33.42					
10	820	36.44	35.47	24 125	34	26	OK
11	800	35.56	55.47	34.125			
12	820	36.44					
13	760	33.78					
14	910	40.44	26.00	24 105	34	26	OV
15	840	37.33	36.22	34.125	54	20	OK
16	750	33.33					
17	840	37.33					
18	800	35.56	25.50	24 105	24	26	OV
19	755	33.56	35.50	34.125	34	26	OK
20	800	35.56					
21	950	42.22					
22	905	40.22	20.20	24.125	24	26	OV
23	790	35.11	39.39	34.125	34	26	OK
24	900	40.00					
25	850	37.78					
26	840	37.33	26.20	24.125	24	26	OV
27	755	33.56	36.28	34.125	34	26	OK
28	820	36.44					
29	890	39.56					
30	840	37.33	0 < 50	24.425			0 11
31	755	33.56	36.72	34.125	34	26	OK
32	820	36.44					



(An ISO 3297: 2007 Certified Organization)

Vol. 4, Issue 1, January 2015

a 1	Failure	Compressive			G 6	
Sample	Load	strength	Average	Deviation	Square of Deviation (x _{individual} -x _{mean}) ²	
No.	(1 N)	(N/mm ²)	0			
	(kN)	Xindividual	X _{mean}	$(\mathbf{x}_{individual} - \mathbf{x}_{mean})$		
1	860	38.22		1.55	2.40939383	
2	740	32.89		-3.78	14.2968012	
3	920	40.89		4.22	17.7990235	
4	800	35.56		-1.11	1.24198642	
5	810	36.00		-0.67	0.4489000	
6	840	37.33		0.66	0.44001111	
7	830	36.89		0.22	0.04791235	
8	840	37.33		0.66	0.44001111	
9	752	33.42		-3.25	10.5480605	
10	820	36.44		-0.23	0.05087531	
11	800	35.56		-1.11	1.24198642	
12	820	36.44		-0.23	0.05087531	
13	760	33.78		-2.89	8.36494938	
14	910	40.44		3.77	14.2464309	
15	840	37.33	36.67	0.66	0.44001111	
16	750	33.33		-3.34	11.1333444	
17	840	37.33		0.66	0.44001111	
18	800	35.56		-1.11	1.24198642	
19	755	33.56		-3.11	9.6997642	
20	800	35.56		-1.11	1.24198642	
21	950	42.22		5.55	30.8271716	
22	905	40.22		3.55	12.6182827	
23	790	35.11		-1.56	2.43013457	
24	900	40.00		3.33	11.0889000	
25	850	37.78		1.11	1.2271716	
26	840	37.33		0.66	0.44001111	
27	755	33.56		-3.11	9.6997642	
28	820	36.44		-0.23	0.05087531	
29	890	39.56		2.89	8.32643086	
30	840	37.33		0.66	0.44001111	
31	755	33.56		-3.11	9.6997642	
32	820	36.44		-0.23	0.05087531	
	Total	1173.42	Total		182.723714	
	Mean	36.67	Established	d SD	2.4278207	

Table 4 Standard deviation calculation



(An ISO 3297: 2007 Certified Organization)

Vol. 4, Issue 1, January 2015



