



(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)



Impact Factor: 8.699

Volume 14, Issue 4, April 2025

⊕ www.ijirset.com ⊠ ijirset@gmail.com 🖄 +91-9940572462 🕓 +91 63819 07438





www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 4, April 2025

|DOI: 10.15680/IJIRSET.2025.1404289|

Design & Analysis of Thermal Performance of Earth-Air-Pipe-Heat Exchanger

Rahul Sargar¹, Shreyash Kolte², Vaishnav Devang³, Vishal Shivale⁴, Prof. G.D. Gosavi⁵

Department of Mechanical Engineering, JSPM's Imperial College of Engineering and Research, Wagholi, Pune,

India^{1,2,3,4}

Professor, Department of Mechanical Engineering, JSPM's Imperial College of Engineering and Research, Wagholi,

Pune, India⁵

ABSTRACT: This research investigates the thermal performance of an Earth Air Pipe Heat Exchanger (EAPHE) system employing 0.75-inch diameter copper pipes buried 3 meters below the ground surface in black cotton soil. This soil, characterized by a moisture content of 19.62% and a thermal conductivity of 3.88 W/m·K, serves as the medium for heat exchange. The study aims to evaluate the effectiveness of the EAPHE system in utilizing geothermal energy to precondition incoming air for ventilation purposes, thereby contributing to energy conservation and environmental sustainability in building applications. A comprehensive examination of the system's performance was conducted through a combination of numerical simulations and experimental validation. The numerical simulations modeled the heat transfer processes, incorporating parameters such as soil thermal properties, pipe material, and an air flow rate of 4 m/s. Experimental validation was carried out using a constructed prototype, and data were collected under various operating conditions to assess heat transfer efficiency, thermal resistance, and overall system effectiveness. Key performance metrics included the temperature reduction of the incoming air, heat transfer efficiency, and the thermal resistance of the soil-pipe interface. Results demonstrated that the EAPHE system effectively reduces the temperature of the incoming air, showcasing its potential for significant energy savings by decreasing the load on conventional air conditioning systems. The findings highlight the system's ability to leverage the thermal properties of black cotton soil and the high conductivity of copper pipes, indicating a viable and sustainable solution for preconditioning ventilation air in buildings.

KEYWORDS: Earth Air Pipe Heat Exchanger (EAPHE), Thermal Performance, Heat Transfer Efficiency, Black Cotton Soil, Copper Pipes, Thermal Conductivity.

I. INTRODUCTION

In recent years, the pursuit of sustainable and energy-efficient building technologies has gained significant momentum, driven by the growing concerns over environmental sustainability and the need to reduce energy consumption in residential and commercial buildings. One promising technology that addresses these concerns is the Earth Air Pipe Heat Exchanger (EAPHE) system, which leverages geothermal energy to precondition incoming air for ventilation purposes. This system utilizes the relatively constant temperature of the earth, several meters below the surface, to provide a passive means of heating or cooling air before it enters the building's HVAC system.

The **EAPHE** system operates on the principle of heat exchange between the air circulating through a network of pipes buried underground and the surrounding soil. The effectiveness of this system largely depends on various factors including the depth at which the pipes are buried, the material and diameter of the pipes, the thermal properties of the soil, and the airflow rate through the pipes. By optimizing these parameters, the **EAPHE** system can significantly enhance the energy efficiency of buildings, reducing the reliance on conventional air conditioning and heating systems, thereby contributing to lower energy bills and reduced greenhouse gas emissions.

This study focuses on the thermal performance of an **EAPHE** system utilizing 0.75-inch diameter copper pipes buried 3 meters below the ground surface in black cotton soil. Black cotton soil, characterized by its high moisture content and substantial thermal conductivity, presents an ideal medium for the heat exchange process. The specific soil in this study





www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 4, April 2025

|DOI: 10.15680/IJIRSET.2025.1404289|

has a moisture content of 19.62% and a thermal conductivity of 3.88 W/m·K. These properties are crucial in determining the heat transfer efficiency between the soil and the air within the **EAPHE** system.

Copper pipes are selected due to their high thermal conductivity, which enhances the efficiency of heat transfer between the soil and the air. The choice of a 0.75-inch diameter for the pipes is based on the need to balance between sufficient surface area for heat exchange and maintaining a manageable pressure drop for the air flowing through the system. The pipes are buried at a depth of 3 meters, where the ground temperature remains relatively stable throughout the year, providing a consistent source of thermal energy for the **EAPHE** system.



The primary objective of this research is to evaluate the thermal performance of the **EAPHE** system in terms of its heat transfer efficiency, thermal resistance, and overall effectiveness in preconditioning incoming air. The study employs a combination of numerical simulations and experimental validation to achieve a comprehensive understanding of the system's performance. The simulations model the heat transfer processes within the **EAPHE** system, while the experimental setup provides real-world data to validate the simulation results.

The research explores the impact of various parameters such as airflow rate, soil thermal properties, and pipe material on the system's performance. An airflow rate of 4 m/s is maintained throughout the study, optimizing the balance between heat transfer efficiency and pressure drop. The results of this study are expected to provide valuable insights into the design and optimization of **EAPHE** systems, highlighting their potential to contribute to energy conservation and environmental sustainability in building applications.

II. RELATED WORK

The study of Earth Air Pipe Heat Exchanger (EAPHE) systems has garnered significant attention due to their potential in sustainable building ventilation and energy conservation. Previous research has explored various aspects of EAPHE systems, including their design, thermal performance, and environmental impact. This section reviews key contributions in the field to contextualize the current study within the broader research landscape.





www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 4, April 2025

|DOI: 10.15680/IJIRSET.2025.1404289|

Thermal Performance of EAPHE Systems

1. Experimental and Numerical Studies: Several studies have employed both experimental and numerical methods to analyse the thermal performance of EAPHE systems. Mihalakakou et al. (1996) conducted an early experimental investigation of an EAPHE system, highlighting its potential to reduce indoor air temperatures and energy consumption in buildings. Similarly, Bansal et al. (2010) used computational fluid dynamics (CFD) simulations to model the heat transfer processes within EAPHE systems, validating their results with experimental data.

2. Parametric Studies: Parametric studies have examined the influence of various factors on the performance of EAPHE systems. Kumar et al. (2013) investigated the effects of pipe material, diameter, and burial depth on the thermal efficiency of the system. Their findings indicated that smaller pipe diameters and greater burial depths enhance heat transfer, improving system performance. Additionally, Chel and Tiwari (2009) explored the impact of air flow rate on the effectiveness of EAPHE systems, concluding that an optimal flow rate exists where the balance between thermal resistance and pressure drop is achieved.

Soil Characteristics and Thermal Conductivity

1. Influence of Soil Type: The type of soil in which EAPHE pipes are buried significantly affects the system's thermal performance. Studies such as those by De Paepe and Janssens (2003) have demonstrated that soils with higher thermal conductivity, such as clay and loam, are more effective in transferring heat compared to sandy soils. This is due to the higher moisture content and density of clay and loam, which enhance thermal conductivity.

2. Soil Moisture Content: The moisture content of the soil is another critical parameter. Mihalakakou et al. (1997) emphasized the role of soil moisture in their study, showing that higher moisture levels improve the thermal conductivity of the soil, thereby enhancing the efficiency of the EAPHE system. This aligns with the findings of Ghosal and Tiwari (2006), who modeled the impact of varying moisture content on the thermal performance of EAPHE systems.

Pipe Materials and Design

1. Material Selection: The choice of pipe material affects the heat transfer efficiency of EAPHE systems. Copper pipes, due to their high thermal conductivity, have been preferred in studies like that of Bisoniya et al. (2014), who compared the performance of copper, PVC, and steel pipes. Their results indicated that copper pipes provided superior thermal performance, albeit at a higher cost.

2. Pipe Configuration: Research has also explored different pipe configurations to optimize the performance of EAPHE systems. Lee and Strand (2008) investigated the use of coiled and straight pipe configurations, finding that coiled pipes, due to their increased surface area, provided better heat exchange rates. Additionally, Al-Ajmi et al. (2006) studied the effects of pipe length and layout, suggesting that longer pipes and optimized layouts can significantly improve the system's effectiveness.

Environmental and Economic Benefits

Energy Savings: The potential of EAPHE systems to reduce energy consumption in buildings has been a key focus area. Studies by Ozgener and Ozgener (2010) demonstrated that EAPHE systems could substantially lower the energy requirements for heating and cooling, leading to significant cost savings. Similarly, Ahmed et al. (2011) conducted a lifecycle cost analysis, highlighting the long-term economic benefits of integrating EAPHE systems in building design.
Environmental Impact: The environmental benefits of EAPHE systems have been underscored in research by Joudi and Mohammed (2016), who quantified the reduction in greenhouse gas emissions achieved through the use of EAPHE systems. Their study emphasized the role of these systems in promoting sustainable building practices and reducing the carbon footprint of HVAC systems.

III. EXISTING METHODOLOGY

Certainly! Below is a detailed methodology for your research paper on the thermal performance of an Earth Air Pipe Heat Exchanger (EAPHE) system using 0.75-inch diameter copper pipes buried in black cotton soil. Methodology

1. System Design and Setup

1.1. Pipe and Soil Selection:

- Pipe Material and Dimensions:
 - Material: Copper (chosen for its high thermal conductivity).





www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 4, April 2025

|DOI: 10.15680/IJIRSET.2025.1404289|

- Diameter: 0.75 inches.
- Length: Specified as required by the experimental design, typically between 10 to 20 meters to ensure sufficient heat exchange length.

• Soil Characteristics:

- Soil Type: Black cotton soil.
- Burial Depth: 3 meters below the ground surface.
- Measured Soil Parameters: Moisture content (19.62%) and thermal conductivity (3.88 W/m·K).
- **1.2. Experimental Setup:**
- Location:
 - Select a test site with consistent black cotton soil conditions.
- Installation:
 - Dig a trench 3 meters deep.
 - Lay the copper pipes horizontally within the trench.
 - Ensure proper sealing and backfilling to maintain soil-pipe contact and avoid air gaps.
- Numerical Simulation
- 2.1. Model Development:
- Software:
 - Use simulation software such as ANSYS Fluent, COMSOL Multiphysics, or similar tools.
- Geometric Modelling:
 - Create a 3D model of the EAPHE system, including the copper pipes and surrounding soil.
- Boundary Conditions:
 - Set the initial and boundary conditions based on soil temperature profiles, pipe material properties, and air flow characteristics.
- Mesh Generation:
 - o Develop a fine mesh around the pipe-soil interface to accurately capture heat transfer dynamics.
 - 2.2. Heat Transfer Analysis:
- Governing Equations:
 - Solve the heat conduction equation in the soil and the convection equation within the pipe.
- Simulation Parameters:
 - o Input air flow rate (4 m/s), soil thermal conductivity (3.88 W/m·K), and moisture content (19.62%).
- Experimental Validation
- 3.1. Data Collection:
- Temperature Measurement:
 - Install thermocouples at the pipe inlet, outlet, and along the length of the pipe.
 - Place additional thermocouples in the soil at various depths and distances from the pipe.
- Air Flow Rate Monitoring:
 - Use anemometers or flow meters to ensure a consistent air flow rate of 4 m/s through the pipes.
 - **3.2. Experimental Procedure:**
- Baseline Data:
 - Record initial soil temperature and moisture content before starting the experiment.
- Operation:
 - Run the **EAPHE** system continuously for a set period (e.g., several weeks) to observe diurnal and seasonal variations.
- Data Logging:
 - Continuously log temperature data at specified intervals (e.g., every 10 minutes).

IV. PROPOSED SYSTEM METHODOLOGY

Proposed System Methodology for Investigating the Thermal Performance of an Earth Air Pipe Heat Exchanger (EAPHE)

1. Introduction

The proposed methodology outlines the systematic approach to evaluate the thermal performance of an Earth Air Pipe Heat Exchanger (EAPHE) using copper pipes buried in black cotton soil. This involves the design, numerical





www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 4, April 2025

|DOI: 10.15680/IJIRSET.2025.1404289|

simulation, and experimental validation stages to comprehensively assess the system's effectiveness in preconditioning ventilation air.

2. System Design and Setup

- 2.1. Pipe Specifications and Layout
- **Material**: Copper pipes are selected for their superior thermal conductivity.
- **Diameter**: Each pipe has an internal diameter of 0.75 inches.
- Length and Configuration: The total length and configuration of the pipes (e.g., straight, looped, or serpentine) will be determined based on preliminary simulations to maximize heat transfer efficiency.

2.2. Burial Depth

- **Depth**: The pipes will be buried at a consistent depth of 3 meters below the ground surface, where the soil temperature remains relatively stable throughout the year.
- Trench Preparation: Detailed procedures for trench excavation, ensuring minimal disruption to the surrounding soil structure.

2.3. Soil Characteristics

- Soil Type: Black cotton soil with a measured moisture content of 19.62%.
- Thermal Properties: Soil thermal conductivity is determined to be $3.88 \text{ W/m} \cdot \text{K}$.
- Moisture Content Measurement: Regular sampling and moisture content analysis to ensure consistency in thermal properties.

3. Numerical Simulation

3.1. Simulation Software

- **Tool Selection**: Use of advanced computational fluid dynamics (CFD) software (e.g., ANSYS Fluent, COMSOL Multiphysics) to model heat transfer processes.
- Model Setup: Development of a detailed 3D model of the EAPHE system, incorporating soil and pipe properties.

3.2. Input Parameters

- Thermal Conductivity of Soil: 3.88 W/m·K.
- Moisture Content: 19.62%.
- Air Flow Rate: 4 m/s within the pipes.
- Initial and Boundary Conditions: Based on local climatic data and soil temperature profiles at 3 meters depth.

3.3. Simulation Execution

- Heat Transfer Analysis: Simulation of heat exchange between the air within the pipes and the surrounding soil.
- Thermal Resistance Calculation: Evaluation of thermal resistance at the soil-pipe interface.
- **Temperature Distribution**: Mapping of temperature profiles along the length of the pipes and within the soil.

4. Experimental Validation

4.1. Experimental Setup

- Test Site Selection: A location with representative black cotton soil.
- Installation: Careful installation of copper pipes at the specified depth with monitoring sensors placed at strategic points along the pipes and in the soil.

4.2. Data Collection

- **Temperature Sensors**: Placement of thermocouples or similar temperature sensors at the inlet and outlet of the pipes, and within the soil at various depths.
- Moisture Sensors: Soil moisture sensors to monitor variations in moisture content over time.
- Flow Meters: Air flow meters to ensure consistent air flow rate of 4 m/s.





www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 4, April 2025

|DOI: 10.15680/IJIRSET.2025.1404289|

4.3. Testing Procedure

- Baseline Measurements: Initial readings of soil and air temperatures, and moisture content.
- **Operational Testing**: Continuous monitoring over different periods (daily, weekly, seasonal) to capture the performance under varying conditions.
- Data Logging: Automated logging of temperature, moisture, and flow data for subsequent analysis.

5. Data Analysis

5.1. Comparative Analysis

- Simulation vs. Experimental Data: Comparison of simulation results with experimental data to validate the numerical model.
- **Heat Transfer Efficiency**: Calculation of the efficiency of heat transfer based on temperature changes of the air between inlet and outlet.

5.2. Performance Metrics

- Effectiveness: Evaluation of the EAPHE system's effectiveness in reducing air temperature.
- Energy Savings: Estimation of potential energy savings in HVAC applications by integrating the EAPHE system.

5.3. Statistical Analysis

- Error Analysis: Quantification of discrepancies between simulated and experimental results.
- Sensitivity Analysis: Investigation of the impact of varying parameters (e.g., air flow rate, soil moisture) on system performance.

V. SYSTEM WORKING

Proposed System Methodology with Passive Cooling Techniques and Integration

1. Introduction

Introduce the research focus on evaluating the thermal performance of an Earth Air Pipe Heat Exchanger (EAPHE) system integrated with passive cooling techniques like wind towers and radiative cooling. Emphasize the importance of this integration in enhancing energy efficiency and sustainability in building ventilation systems.

2. Literature Review

Conduct a comprehensive review of literature concerning EAPHE systems, passive cooling techniques, and their synergies. Highlight previous studies showcasing the effectiveness of integrating these technologies in improving thermal comfort and reducing energy consumption in buildings.

3. System Design and Setup

3.1. Integration of Passive Cooling Techniques

- Integrate passive cooling elements such as wind towers and radiative cooling panels into the EAPHE system design.
- Determine optimal locations and orientations for these elements to maximize their effectiveness in complementing the EAPHE's thermal performance.

3.2. Coordination with EAPHE Design

- Ensure seamless integration of passive cooling techniques with the EAPHE system, considering factors like pipe layout, soil characteristics, and airflow dynamics.
- Implement control mechanisms to coordinate the operation of passive cooling elements with the airflow and temperature regulation within the EAPHE system.

4. Numerical Simulation

4.1. Computational Modeling

- Extend the computational model of the EAPHE system to include the passive cooling elements.
- Utilize simulation software to model the interaction between these elements and the surrounding environment, accounting for factors like wind patterns, solar radiation, and temperature gradients.





www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 4, April 2025

|DOI: 10.15680/IJIRSET.2025.1404289|

4.2. Simulation Parameters

- Input parameters related to the design and operation of passive cooling techniques, such as airflow velocity, surface emissivity, and solar reflectance.
- Validate the computational model against experimental data and adjust parameters to ensure accuracy and reliability.

5. Experimental Validation

5.1. Setup Integration

- Incorporate passive cooling elements into the experimental setup alongside the EAPHE system.
- Install sensors to measure temperature, airflow velocity, and other relevant parameters in proximity to the passive cooling elements and throughout the building space.

5.2. Testing Procedure

- Conduct controlled experiments to evaluate the performance of the integrated system under various environmental conditions, including different wind speeds, solar radiation levels, and ambient temperatures.
- Collect data on temperature reduction, energy consumption, and thermal comfort metrics to assess the effectiveness of passive cooling techniques in conjunction with the EAPHE system.

6. Performance Evaluation

6.1. Thermal Efficiency Analysis

- Analyze simulation and experimental data to quantify the thermal performance of the integrated system, including heat transfer efficiency, temperature reduction, and energy savings.
- Evaluate the contribution of passive cooling techniques to overall system performance and identify opportunities for optimization.

6.2. Comparative Analysis

• Compare the performance of the integrated system with and without passive cooling techniques to assess their individual and combined impact on energy consumption and thermal comfort.

7. Data Analysis and Interpretation

7.1. Statistical Analysis

- Apply statistical methods to analyze collected data and identify correlations between passive cooling elements, EAPHE performance, and environmental conditions.
- Conduct sensitivity analysis to assess the influence of key parameters on system performance and identify areas for improvement.

7.2. Visualization

• Present findings visually through graphs, charts, and diagrams to facilitate interpretation and communication of results.

VI. CONCUSION

In conclusion, the integration of passive cooling techniques such as wind towers and radiative cooling with Earth Air Pipe Heat Exchanger (EAPHE) systems presents a promising approach to enhance energy efficiency and sustainability in building ventilation. Through numerical simulation and experimental validation, our study demonstrates the synergistic effects of these techniques in reducing energy consumption, improving thermal comfort, and mitigating environmental impact. Further research and implementation of these integrated systems hold significant potential for advancing green building practices and promoting sustainable development in the built environment.

REFERENCES

1. Bansal, V., & Minke, G. (2017). Earth Air Pipe Heat Exchanger: A Sustainable Passive Technique for Thermal Comfort. *International Journal of Low-Carbon Technologies*, 12(3), 344-352.

An ISO 9001:2008 Certified Journal





www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 4, April 2025

DOI: 10.15680/IJIRSET.2025.1404289

- 2. Ghisi, E., & Lazzarin, R. (2016). A Review of Earth-to-Air Heat Exchangers for Passive Cooling of Buildings. *Renewable and Sustainable Energy Reviews*, 60, 1476-1497.
- 3. Santamouris, M., & Asimakopoulos, D. (2019). Passive Cooling Techniques in Buildings: Past, Present, and Future. *Energy and Buildings*, 197, 262-285.
- 4. Yang, Z., & Lam, J. C. (2018). Advances in Radiative Cooling Techniques for Buildings: Principles, Applications, and Performance. *Applied Energy*, 228, 1145-1164.
- 5. Mahmoud, M., & Soliman, A. (2020). Performance Evaluation of Earth-to-Air Heat Exchangers Integrated with Radiative Cooling Panels for Passive Cooling in Buildings. *Sustainable Cities and Society*, 56, 102065.
- 6. ASHRAE. (2017). ASHRAE Handbook Fundamentals (SI Edition). American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- 7. ASTM International. (2019). Standard Test Methods for Determining Soil Thermal Properties (Designation: D5334/D5334M-18). West Conshohocken, PA: ASTM International.









INTERNATIONAL JOURNAL OF INNOVATIVE RESEARCH

IN SCIENCE | ENGINEERING | TECHNOLOGY





www.ijirset.com