



International Journal of Innovative Research in Science Engineering and Technology (IJIRSET)

(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)



Impact Factor: 8.699

Volume 14, Issue 12, December 2025

Architecting the Self-Healing Grid: A Holistic Framework for Intelligent Energy Grids and Autonomous Power Systems

S. Sujitha

Assistant Professor, Department of EEE, NPR College of Engineering and Technology, Natham, Dindigul,
Tamilnadu, India

ABSTRACT: The global energy landscape is undergoing a profound transformation, driven by the dual imperatives of decarbonization and digitalization. The integration of intermittent renewable energy sources, the proliferation of distributed energy resources (DERs), and the emergence of new load types like electric vehicles (EVs) are pushing traditional, centralized power grids beyond their operational limits. In response, the concepts of the Intelligent Energy Grid (IEG) and the Autonomous Power System (APS) have emerged as critical paradigms for a sustainable, resilient, and efficient energy future.

This research paper presents a comprehensive investigation into the architectural, technological, and operational foundations of IEGs and APSs. We begin with a detailed literature survey that traces the evolution from the traditional grid to the smart grid and now to the intelligent, autonomous grid. The core contribution of this work is a novel, integrated framework that synergizes a multi-agent system (MAS) for decentralized control with a hierarchical analytics stack for system-wide intelligence. This framework is designed to enable real-time self-optimization, self-healing, and adaptive protection.

Our methodology involves the development of a high-fidelity co-simulation testbed integrating PowerFactory for electrical domain simulation, MATLAB for control algorithm development, and MQTT brokers for communication emulation. We model a benchmark IEEE 33-bus distribution system modified with high penetration of solar PV, wind generation, and EV charging stations. The results of our simulation analysis demonstrate the efficacy of the proposed framework.

In scenario testing, the system successfully contained a fault through autonomous reconfiguration, reducing the number of affected customers by 85% compared to a traditional grid response. Furthermore, the MAS-based energy market achieved a 22% reduction in locational marginal prices during peak renewable generation hours by efficiently utilizing local DERs. The results also highlight critical challenges, including communication latency and cybersecurity threats, which can destabilize the system if not adequately mitigated. This study concludes that the transition to IEGs and APSs is not merely a technological upgrade but a fundamental architectural shift.

It requires the deep integration of advanced sensing, communication, and artificial intelligence to create a grid that is not only smarter but truly cognitive and self-sufficient, paving the way for a fully decentralized and resilient energy ecosystem.

KEYWORDS: Intelligent Energy Grid, Autonomous Power System, Multi-Agent System, Distributed Energy Resources, Self-Healing, Decentralized Control, Cyber-Physical Security, Transactive Energy.

I. INTRODUCTION

The 20th-century power grid, a marvel of engineering, was designed for a different era. Characterized by centralized, unidirectional power flow from large-scale fossil fuel and nuclear power plants to passive consumers, it operated on principles of predictability and top-down control [1]. This model is now fundamentally challenged. The urgent global mandate to mitigate climate change has accelerated the deployment of variable renewable energy sources (VRES) like solar and wind. Simultaneously, at the distribution level, a revolution is underway with the rise of prosumers—

consumers who also produce energy—equipped with rooftop solar panels, home battery storage, and electric vehicles [2].

This paradigm shift introduces unprecedented complexity and volatility. The centralized "generate-transmit-distribute" model is ill-suited to handle bidirectional power flows, the spatial and temporal uncertainty of solar and wind generation, and the massive, stochastic load demands of uncontrolled EV charging [3]. Consequences include voltage violations, frequency instability, thermal overloading of assets, and reduced system resilience. The August 2019 UK blackout, partially attributed to the simultaneous loss of multiple distributed generation sources, serves as a stark reminder of these new vulnerabilities [4].

In response, the concept of the "Smart Grid" emerged over a decade ago, focusing on the integration of digital communication technologies and advanced metering infrastructure (AMI) to provide better visibility and control [5]. However, the current state of smart grids often represents an incremental improvement rather than a transformative leap. Many systems still rely heavily on centralized Supervisory Control and Data Acquisition (SCADA) systems, which can be slow, brittle, and present a single point of failure.

This has led to the vision of the **Intelligent Energy Grid (IEG)** and its ultimate evolution, the **Autonomous Power System (APS)**. An IEG is not merely a grid with sensors; it is a cyber-physical system that leverages pervasive sensing, high-speed communication, and artificial intelligence (AI) to perform real-time analytics, predictive optimization, and informed decision-making [6].

Building upon this intelligence, an APS embodies the principles of autonomy, where the grid can perform critical functions—such as fault isolation and service restoration (self-healing), voltage regulation (self-optimization), and defense against cyber-attacks (self-protection)—with minimal to no human intervention [7].

The transition to such systems is fraught with technical, regulatory, and economic challenges. These include designing robust decentralized control architectures, ensuring interoperability between a multitude of devices and protocols, guaranteeing cybersecurity in an exponentially expanded attack surface, and creating market structures that incentivize participation [8].

This research paper aims to address the core technical challenges by proposing and evaluating an integrated framework for IEGs and APSs. The primary research questions are:

1. What is an effective architectural framework that can seamlessly integrate decentralized control with system-wide intelligence for an IEG?
2. How can such a framework demonstrate superior performance in terms of resilience, efficiency, and stability under high DER penetration compared to traditional and smart grid approaches?
3. What are the key technological and operational barriers to achieving full autonomy, and how can they be mitigated?

The paper is organized as follows: Section 2 provides a comprehensive literature review; Section 3 details the proposed methodology and framework; Section 4 presents the simulation results and analysis; and Section 5 concludes with findings and future research directions.

II. LITERATURE SURVEY

2.1 From Smart Grid to Intelligent and Autonomous Grids

The **Smart Grid** has been extensively defined in the literature. According to the U.S. NIST, it is a "modernized grid that enables bidirectional flows of energy and uses two-way communication and control capabilities that will lead to an array of new functionalities and applications" [5]. Key enabling technologies include Advanced Metering Infrastructure (AMI), Phasor Measurement Units (PMUs), and distribution automation systems. While these provide enhanced monitoring, decision-making often remains centralized and human-in-the-loop.

The **Intelligent Energy Grid (IEG)** represents a maturation of the smart grid concept. Intelligence implies the ability to learn from data, reason about system states, and make informed decisions. Farag et al. [6] describe the IEG as a system that employs AI and Machine Learning (ML) for applications like load forecasting, asset management, and anomaly detection. Deep learning models, particularly Long Short-Term Memory (LSTM) networks, have shown

remarkable success in short-term load forecasting and solar generation prediction, providing the predictive capability necessary for proactive control [9].

The **Autonomous Power System (APS)** is the ultimate embodiment of grid modernization. Autonomy refers to the system's ability to perform complex tasks independently. The Self-Healing Grid, a key attribute of an APS, has been a focus of research for utilities like the American Electric Power (AEP), which pioneered the "Grid of the Future" concept [10]. APS research draws inspiration from other complex autonomous systems, such as robotics and unmanned aerial vehicles, applying concepts like hierarchical control loops and multi-agent systems.

2.2 Architectural Paradigms: Centralized vs. Distributed Control

The control architecture is the backbone of grid operations. The traditional **centralized control** model, epitomized by SCADA and Energy Management Systems (EMS), collects data from remote terminal units (RTUs) and issues control commands from a central control center [1]. While effective for a simpler grid, this architecture suffers from scalability issues, communication bottlenecks, and vulnerability to single-point failures, making it unsuitable for a dynamic, distributed future.

Decentralized and Distributed Control paradigms have gained significant traction. In a decentralized architecture, control actions are determined locally based on local measurements and limited communication with neighbors. **Multi-Agent Systems (MAS)** are a prominent implementation of this paradigm, where autonomous software agents representing physical assets (e.g., a solar inverter, an EV charger, a feeder controller) collaborate and negotiate to achieve system-wide objectives [11]. McArthur et al. [12] provide a comprehensive review of MAS applications in power engineering, highlighting their use in restoration, voltage control, and market operations. Frameworks like the IEEE Foundation for Intelligent Physical Agents (FIPA) standards provide a basis for agent communication and interoperability.

2.3 Key Technological Enablers

- **Internet of Things (IoT) and Sensing:** The proliferation of low-cost, intelligent sensors embedded in grid assets (transformers, reclosers, DERs) and consumer premises provides the granular, real-time data required for intelligence. IoT protocols like Message Queuing Telemetry Transport (MQTT) and Constrained Application Protocol (CoAP) are designed for efficient, low-power machine-to-machine (M2M) communication [13].
- **Communication Networks:** A reliable, low-latency, and high-bandwidth communication infrastructure is the nervous system of the IEG. This involves a hybrid of technologies: fiber optics for backbone communication, cellular networks (5G for ultra-reliable low-latency communication - URLLC), and wireless mesh networks for last-mile connectivity [14].
- **Artificial Intelligence and Data Analytics:** AI is the brain of the IEG. Beyond forecasting, ML is used for:
 - **Anomaly Detection:** Identifying cyber-attacks or equipment failures [15].
 - **Reinforcement Learning (RL):** For developing autonomous control policies for DERs and storage [16].
 - **Optimization:** Solving complex, non-linear problems like optimal power flow (OPF) in real-time.
- **Blockchain and Transactive Energy:** Blockchain technology offers a decentralized, transparent, and secure platform for implementing transactive energy markets. It enables peer-to-peer (P2P) energy trading between prosumers and consumers, creating economic signals that drive efficient DER utilization [17].

2.4 Challenges and Research Gaps

Despite the promising research, significant gaps remain. Many proposed MAS solutions are tested in simplified environments and lack integration with realistic communication network models [18]. The **cyber-physical security** of IEGs is a paramount concern; a coordinated attack on communication links can mislead agents and cause physical grid failure [19]. Furthermore, the transition pathway from today's grid to a fully autonomous one is unclear, requiring significant regulatory evolution and standardization [20]. This paper seeks to address the simulation fidelity gap by employing a co-simulation platform and explicitly modeling the cyber-physical interactions and their impact on autonomy.

III. METHODOLOGY

This research employs a model-based design and simulation approach to develop and evaluate the proposed framework for an IEG/APS. Given the cyber-physical nature of the system, a co-simulation environment is essential to accurately capture the interactions between the physical power grid, the communication network, and the control intelligence.

3.1 Proposed Integrated Framework for IEG/APS

We propose a hierarchical, hybrid architecture that combines the global oversight of a centralized system with the resilience and speed of decentralized control. The framework consists of three primary layers:

1. **Physical Layer:** The electrical infrastructure itself—lines, cables, transformers, circuit breakers, loads, generators, DERs, and storage.
2. **Cyber-Physical Control Layer (Decentralized):** This is the core autonomous layer, implemented as a Multi-Agent System (MAS). It is organized into hierarchical communities:
 - **Micro-Agents:** Represent individual assets (e.g., PVInverterAgent, EVChargingAgent, SmartHomeAgent). They are responsible for local control and can participate in local markets.
 - **Feeder-Level Agents:** Represent a segment of the distribution feeder (e.g., *Feeder ControllerAgent*). They aggregate information from Micro-Agents, perform state estimation for their zone, and execute commands like voltage regulation via reactive power control.
 - **Substation-Level Agent:** The highest-level agent in the MAS, acting as a coordinator. It handles interconnection with the bulk transmission system, manages islanding detection, and oversees large-scale restoration efforts.
3. **Cloud-Based Intelligence Layer (Centralized):** This layer provides system-wide "slow-thinking" intelligence. It uses historical and real-time data from the MAS to run digital twin simulations, perform long-term forecasting with AI models, optimize asset maintenance schedules, and update the control policies for the agents in the lower layer via periodic downloads.




Figure 1: Proposed Hierarchical Hybrid Architecture for an Autonomous Power System

3.2 Co-Simulation Testbed Development

To test this framework, we developed a co-simulation testbed using the following tools, synchronized via the Functional Mock-up Interface (FMI) standard:

- **PowerFactory (DigSILENT):** Used for modeling the electrical behavior of the distribution network. It provides high-fidelity simulation of power flow, dynamics, and fault analysis.
- **MATLAB/Simulink:** Used to implement the control logic for the Multi-Agent System. The MATLAB Agent-Based Simulation framework is used to model the behaviors, interactions, and decision-making processes of all agents.
- **OMNeT++:** Used to model the communication network, including packet routing, delays, packet loss, and bandwidth constraints on a 5G and fiber optic hybrid network.
- **MQTT Broker (Eclipse Mosquitto):** Embedded within the co-simulation to emulate the lightweight publish-subscribe messaging protocol used for agent-to-agent communication.




Figure 2: Co-Simulation Testbed Architecture

3.3 System Model and Scenario Design

We model a modified IEEE 33-bus radial distribution system as our test case. The base system is adapted to reflect modern challenges:

- **DER Integration:** 8 distributed solar PV systems (total penetration of 60% of peak load) and 2 small wind turbines are connected at various buses.
- **EV Load:** 5 bus locations are designated as EV charging stations, modeling a collective load that can reach 30% of peak system load.
- **Storage:** 2 community battery energy storage systems (BESS) are placed at strategic locations for peak shaving and voltage support.

We design and simulate three key scenarios to evaluate the framework's performance:

1. **Scenario A: Self-Healing and Fault Management:** A three-phase fault is applied to a main feeder. We compare the system response of our MAS-based framework against a traditional protection scheme (reclosers and fuses).
2. **Scenario B: Real-Time Optimization and Transactive Energy:** Simulates a 24-hour period with high solar generation at midday and high EV charging demand in the evening. We evaluate the system's ability to maintain voltage within limits and minimize energy costs through a local transactive energy market run by the MAS.
3. **Scenario C: Cyber-Physical Resilience:** A False Data Injection (FDI) attack is launched against the communication links of several PV agents, providing them with false voltage measurements. We analyze the system's ability to detect and mitigate this attack using distributed consensus algorithms among the Feeder-Level Agents.

3.4 Performance Metrics

The following metrics are used for quantitative analysis:

- **Resilience:** Customer Average Interruption Duration Index (CAIDI), Number of Customers Interrupted (NCI), and Service Restoration Time.
- **Power Quality:** Voltage Deviation Index (VDI), Total Harmonic Distortion (THD).

- **Economic Efficiency:** Locational Marginal Price (LMP), Cost of Energy Purchased from the Transmission Grid, Utilization Rate of DERs.
- **Cyber-Physical Performance:** Communication Latency, Packet Delivery Ratio, False Positive/Negative Rate of attack detection.

IV. RESULT ANALYSIS

4.1 Scenario A: Self-Healing and Fault Management Performance

The results from the fault scenario demonstrate a dramatic improvement in resilience. In the traditional grid model, the fault on the main feeder caused a sustained outage for all 650 customers downstream of the protective device, with a restoration time of 45 minutes (simulating a crew dispatch).

In the proposed APS model, the sequence of autonomous actions was as follows:

1. **Fault Detection and Isolation:** Micro-agents near the fault detected the voltage sag and current spike. The Feeder-Level Agent corroborated this data and, within 100 milliseconds, commanded circuit breakers to isolate the smallest possible faulted section.
2. **Service Restoration:** The Substation-Level Agent, now aware of the islanded section, immediately initiated a restoration sequence. It commanded a normally open tie-switch to close, re-energizing the healthy portion of the downstream network from an adjacent feeder. Simultaneously, it dispatched the local BESS and requested DERs in the isolated section to form a microgrid if possible.

Table 1: Self-Healing Performance Comparison

Metric	Traditional Grid	Proposed APS	Improvement
Customers Initially Interrupted	650	650	-
Customers After Restoration	650	95	85% Reduction
Service Restoration Time	45 minutes	45 seconds	98.3% Faster
Energy Not Supplied (MWh)	4.87	0.71	85.4% Reduction

The APS successfully restored power to 555 customers in under a minute, leaving only the 95 customers directly on the faulted segment without power until physical repairs were made.




Figure 3: Voltage Profile During and After Fault Event

4.2 Scenario B: Real-Time Optimization and Transactive Energy

The 24-hour simulation revealed the framework's superior efficiency. During midday, with solar generation at its peak, the traditional grid model experienced significant voltage rise (up to 1.08 p.u.) at buses with high PV penetration, threatening equipment and leading to potential inverter tripping.

In the APS model, the Feeder-Level Agents detected the rising voltage and initiated a transactive energy market. They broadcast a request for reactive power absorption and/or real power curtailment. PV agents and BESS agents bid into this market based on their cost functions. The market cleared, dispatching resources to inject inductive reactive power, which successfully suppressed the voltage to within 1.05 p.u. without excessive curtailment of real power.

During the evening peak, the high demand from EV charging caused voltage drops. The MAS responded by discharging the BESS and having DERs inject both real and reactive power, maintaining voltage above 0.95 p.u. Economically, the local energy transactions reduced the need to purchase expensive power from the transmission grid.

Table 2: Economic and Power Quality Results (24-hour Period)

Metric	Traditional Grid	Proposed APS
Average Locational Marginal Price (peak hours)	\$125/MWh	\$97.5/MWh
Total Cost of Transmission Energy	\$18,450	\$14,392
Time Outside Voltage Limits (1.05-0.95 p.u.)	4.7 hours	0.2 hours
PV Energy Curtailed (due to overvoltage)	18.5 MWh	5.1 MWh

24-Hour Locational Marginal Price Comparison




Figure 4: 24-Hour Locational Marginal Price (LMP) Comparison

4.3 Scenario C: Cyber-Physical Resilience

The FDI attack simulation exposed a critical vulnerability but also validated the proposed mitigation. When several PV agents received false data indicating low voltage, they increased their reactive power output in an attempt to provide support, which in reality drove the voltage up dangerously in their region.

However, the Feeder-Level Agent, which performs distributed state estimation using data from all sensors in its zone, identified an inconsistency. It could not reconcile the voltage measurements from the compromised PV agents with

those from other, trusted micro-agents (e.g., at smart meters). Triggering a consensus protocol with neighboring Feeder-Level Agents, it identified and isolated the compromised agents within 5 seconds. Control was temporarily handed off to the Cloud Intelligence Layer, which provided a corrected state estimate, allowing the system to stabilize. While this caused a temporary disturbance, it prevented a widespread blackout.

4.4 Synthesis and Discussion

The results collectively demonstrate that the integrated MAS-based framework provides a robust foundation for APS. The key strength lies in its resilience and speed of response to physical contingencies, as shown in Scenario A. The transactive energy mechanism in Scenario B proves that economic signals can be effectively used for real-time technical control, enhancing efficiency and power quality.

However, the study also highlights non-trivial challenges:

- **Communication Dependency:** The system's performance is heavily reliant on low-latency, high-reliability communication. In simulations where we introduced significant packet loss (>15%) in OMNeT++, the MAS coordination degraded, leading to slower response times and, in some cases, oscillatory behavior.
- **Cybersecurity is Paramount:** Scenario C underscores that the expanded cyber-attack surface is the Achilles' heel of the IEG. Decentralized intrusion detection and mitigation must be a core design principle, not an afterthought.
- **Computational Complexity:** Running a fully distributed optimization and consensus for a large-scale system in real-time remains computationally intensive. Future work must focus on developing lightweight AI models and efficient algorithms.

V. CONCLUSION

This research has presented a comprehensive investigation into the architectural and operational principles of Intelligent Energy Grids and Autonomous Power Systems. Through the development of a novel hierarchical framework and its validation in a high-fidelity co-simulation environment, we have demonstrated the transformative potential of integrating decentralized Multi-Agent control with cloud-based intelligence. The results unequivocally show that such a system can significantly outperform traditional and first-generation smart grids in critical areas of resilience, efficiency, and power quality.

The proposed framework enabled an 85% reduction in outage customers and a 98% faster restoration through autonomous self-healing. It maintained superior voltage profiles and reduced energy costs by 22% during peak periods by leveraging a transactive energy market. These are not incremental improvements but step-changes that address the core challenges of the 21st-century power system.

5.1 Implications and Future Work

The findings have significant implications for utilities, regulators, and technology providers:

- **For Utilities:** The transition to an APS requires a strategic shift from pure asset management to the management of a complex cyber-physical ecosystem. Investments must be directed toward communication infrastructure, data analytics platforms, and workforce retraining.
- **For Regulators:** New regulatory models are needed to incentivize investments in grid intelligence and to enable novel business models like transactive energy and P2P trading.
- **For Researchers:** This work opens several avenues for future research. These include:
 1. **Standardization and Interoperability:** Developing universal communication standards and data models for agents to ensure plug-and-play compatibility of DERs.
 2. **Explainable AI (XAI):** Creating AI models whose decisions can be understood and trusted by human operators, which is crucial for the acceptance of autonomous actions.
 3. **Quantum Computing:** Exploring the application of quantum algorithms for solving the complex, non-linear optimization problems of the grid in real-time.
 4. **Socio-Technical-Economic Modeling:** Studying the consumer acceptance, market design, and regulatory frameworks needed to support a fully decentralized energy economy.

In conclusion, the journey towards fully autonomous power systems is complex and multifaceted. It is a journey from a centralized, brittle machine to a distributed, intelligent, and resilient organism. This research has contributed a validated

architectural framework and a deeper understanding of the associated challenges, providing a concrete step forward in the realization of a sustainable, secure, and self-sufficient energy future.

REFERENCES

- [1]. A. Bose, "Smart transmission grid applications and their supporting infrastructure," IEEE Trans. Smart Grid, vol. 1, no. 1, pp. 11–19, Jun. 2010.
- [2]. S. Chowdhury, S. P. Chowdhury, and P. Crossley, Microgrids and Active Distribution Networks. London, U.K.: IET, 2009.
- [3]. P. Siano, "Demand response and smart grids—A survey," Renew. Sustain. Energy Rev., vol. 30, pp. 461–478, Feb. 2014.
- [4]. "Technical Report on the Events of 9 August 2019," National Grid ESO, UK, 2019.
- [5]. "NIST Framework and Roadmap for Smart Grid Interoperability Standards, Release 3.0," NIST Special Publication 1108r3, 2014.
- [6]. H. E. Farag, E. F. El-Saadany, R. Seethapathy, and M. M. A. Salama, "A novel control algorithm for the DG interface to mitigate power quality problems," IEEE Trans. Power Del., vol. 26, no. 4, pp. 2240–2251, Oct. 2011.
- [7]. A. G. Phadke and J. S. Thorp, Synchronized Phasor Measurements and Their Applications. New York, NY, USA: Springer, 2008.
- [8]. V. C. Gungor et al., "A survey on smart grid potential applications and communication requirements," IEEE Trans. Ind. Informat., vol. 9, no. 1, pp. 28–42, Feb. 2013.
- [9]. Z. Yu, L. Jia, M. C. Murphy-Hoye, A. Pratt, and L. Tong, "Modeling and stochastic control for home energy management," IEEE Trans. Smart Grid, vol. 4, no. 4, pp. 2244–2255, Dec. 2013.
- [10]. M. McGranaghan, D. Von Dollen, P. Myrda, and E. Gunther, "Utility experience with developing a smart grid roadmap," in Proc. IEEE Power Energy Soc. Gen. Meet., 2008, pp. 1–5.
- [11]. S. D. J. McArthur et al., "Multi-agent systems for power engineering applications—Part I: Concepts, approaches, and technical challenges," IEEE Trans. Power Syst., vol. 22, no. 4, pp. 1743–1752, Nov. 2007.
- [12]. S. D. J. McArthur et al., "Multi-agent systems for power engineering applications—Part II: Technologies, standards, and tools for building multi-agent systems," IEEE Trans. Power Syst., vol. 22, no. 4, pp. 1753–1759, Nov. 2007.
- [13]. A. Al-Fuqaha, M. Guizani, M. Mohammadi, M. Aledhari, and M. Ayyash, "Internet of Things: A survey on enabling technologies, protocols, and applications," IEEE Commun. Surveys Tuts., vol. 17, no. 4, pp. 2347–2376, 4th Quart., 2015.
- [14]. Biagini, Veronica, Milos Subasic, Alexandre Oudalov, and Jochen Kreusel. "The autonomous grid: Automation, intelligence and the future of power systems." Energy Research & Social Science 65 (2020): 101460.
- [15]. Rahman, Saifur, Manisa Pipattanasomporn, and Yonael Teklu. "Intelligent distributed autonomous power systems (IDAPS)." In 2007 IEEE Power Engineering Society General Meeting, pp. 1-8. IEEE, 2007.
- [16]. Kroposki, Benjamin, Andrey Bernstein, Jennifer King, Deepthi Vaidhynathan, Xinyang Zhou, Chin-Yao Chang, and Emiliano Dall'Anese. "Autonomous energy grids: Controlling the future grid with large amounts of distributed energy resources." IEEE Power and Energy Magazine 18, no. 6 (2020): 37-46.
- [17]. Cavus, Muhammed. "Advancing Power Systems with Renewable Energy and Intelligent Technologies: A Comprehensive Review on Grid Transformation and Integration." Electronics 14, no. 6 (2025): 1159.
- [18]. Zhong, Qing-Chang. Power electronics-enabled autonomous power systems: next generation smart grids. John Wiley & Sons, 2020.
- [19]. Kroposki, Benjamin D., Emiliano Dall-Anese, Andrey Bernstein, Yingchen Zhang, and Brian S. Hodge. Autonomous energy grids. No. NREL/CP-5D00-68712. National Renewable Energy Lab.(NREL), Golden, CO (United States), 2017.
- [20]. McArthur, Stephen DJ, Philip C. Taylor, Graham W. Ault, James E. King, Dimitrios Athanasiadis, Varavara D. Alimisis, and Maciej Czaplewski. "The Autonomic Power System-Network operation and control beyond smart grids." In 2012 3rd IEEE PES Innovative Smart Grid Technologies Europe (ISGT Europe), pp. 1-7. IEEE, 2012.



INTERNATIONAL
STANDARD
SERIAL
NUMBER
INDIA



INTERNATIONAL JOURNAL OF INNOVATIVE RESEARCH

IN SCIENCE | ENGINEERING | TECHNOLOGY

 9940 572 462  6381 907 438  ijirset@gmail.com



www.ijirset.com

Scan to save the contact details