



International Journal of Innovative Research in Science Engineering and Technology (IJIRSET)

(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)



Impact Factor: 8.699

Volume 14, Issue 5, May 2025

⊕ www.ijirset.com 🖂 ijirset@gmail.com 🖄 +91-9940572462 🕓 +91 63819 07438



International Journal of Innovative Research of Science, Engineering and Technology (IJIRSET)



www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 5, May 2025

|DOI: 10.15680/IJIRSET.2025.1405250|

Fault Detection and Protection of Three Phase Induction Motor using Delta PLC

Abhishek H S, Arunkumar Biradar, Manjunatha D, Pavan K R

U.G Students, Department of Electrical and Electronics Engineering, Channabasaveshwara Institute of Technology,

Gubbi, Tumkur, Karnataka, India

Janardhan L. K

Assistant Professor, Department of Electrical and Electronics Engineering, Channabasaveshwara Institute of

Technology, Gubbi, Tumkur, Karnataka, India

ABSTRACT: This paper presents a programmable logic controller (PLC)-based system for the real-time fault detection and protection of three-phase induction motors. The proposed approach enhances motor safety by identifying common faults such as phase loss, overcurrent, and overheating. Utilizing PLC technology ensures rapid response and increased reliability in industrial applications. Sensor data is continuously monitored and processed to initiate protective measures when abnormal conditions are detected. The system architecture allows for easy scalability and integration with existing control frameworks. Emphasis is placed on minimizing motor downtime and reducing maintenance costs. Experimental validation demonstrates the effectiveness and accuracy of the fault detection mechanism. The study highlights the advantages of automation in motor protection compared to conventional relay-based systems. This work contributes to improving operational efficiency and equipment longevity in automated environments.

KEYWORDS: Fault detection, protection system, PLC, three-phase induction motor, automation, motor monitoring.

I. INTRODUCTION

Three-phase induction motors are widely used in industrial automation due to their durability, low cost, and ease of operation. However, their reliability can be compromised by various electrical and mechanical faults such as phase imbalance, overcurrent, overvoltage, undervoltage, and thermal overload. Conventional protection systems using electromechanical relays or manual supervision are often inadequate. This paper explores the implementation of a PLC-based protection scheme capable of real-time fault detection and mitigation.

By integrating real-time control with intelligent diagnostics, this project not only enhances the operational life of induction motors but also supports the broader goals of industrial safety and automation efficiency.

II. LITERATURE REVIEW

The three-phase induction motor is widely used in industrial and commercial applications due to its simple construction, low cost, and high reliability. However, like all electromechanical devices, it is prone to faults such as phase loss, overload, voltage imbalance, and overheating. Over the years, various approaches have been explored to detect and protect against these faults, ranging from basic relay-based systems to advanced automation using PLCs and microcontrollers. This section reviews the key research contributions in this field and the role of programmable logic controllers, particularly Delta PLCs, in improving fault detection and protection mechanisms.

Prior studies have emphasized the importance of early fault detection to prevent motor failure. PLCs offer advantages such as programmability, flexibility, and seamless integration with sensors. successful detection of motor faults using current and temperature sensors interfaced with PLCs. However, there remains a need for cost-effective, scalable solutions tailored for various industrial setups.



International Journal of Innovative Research of Science, Engineering and Technology (IJIRSET)



www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 5, May 2025

|DOI: 10.15680/IJIRSET.2025.1405250|

III. SYSTEM DESIGN AND METHODOLOGY

3.1 Hardware Configuration

The system incorporates a three-phase induction motor, current transformers, voltage sensors, temperature sensors (e.g., LM35), and a Delta PLC. The sensors collect real-time data, which is processed by the PLC to detect faults bas ed on preset thresholds.

3.2 Software Implementation

Using ladder logic, fault conditions such as overcurrent, overvoltage, phase loss, and overtemperature are encoded. On detection of anomalies, the PLC triggers an alarm and isolates the motor via a contactor, thus protecting the system.

IV. STRUCTURAL DESIGN

The system is built inside a control panel, housing all electrical and electronic components in a safe and organized layout. The panel includes the Delta DVP-PLC, thermal overload relay, miniature electromagnetic relay, voltage monitoring relay, temperature controller, and power supply module. All components are mounted on a DIN rail for easy access and maintenance.

Wiring is carried out in such a way as to minimize electromagnetic interference and short circuits. Control signals are separated from power lines, and all wiring is color-coded and labelled for clarity. The user interface includes push buttons for Start, Stop, and Reset operations, along with LED indicators to display motor and fault status.

The Delta PLC is programmed using WPLSoft, Delta's ladder logic programming environment. The ladder diagram includes inputs from relays and sensors, and outputs to control relays, alarm systems, and HMI interfaces if used. The modular design of the system allows easy expansion or adaptation to different motor ratings and applications.

V. WORKING MECHANISM

The core of the protection system revolves around the Delta DVP-PLC, which processes input signals from various sensing components and outputs control signals to actuate relays or alarms. The system works as follows:

A voltage monitoring relay checks the input three-phase supply for abnormalities such as phase failure, under-voltage, or over-voltage. If any deviation is detected, the relay sends a signal to the PLC, which in turn stops the motor to prevent damage.

A thermal overload relay is placed in series with the motor to monitor the current. When current exceeds the rated value for a sustained period, it trips and signals the PLC to shut down the motor.

A temperature controller monitors the motor casing temperature via a sensor, such as a thermocouple or RTD. If the temperature crosses a preset limit, the controller sends a high signal to the PLC.

Based on these inputs, the PLC evaluates fault conditions using pre-programmed ladder logic. When any fault is detected, it deactivates the miniature electromagnetic relay or contactor, thereby cutting power to the motor. Simultaneously, the PLC activates alarms and indicators such as buzzers or LED lights to alert the operator.

Additionally, voltmeters and ammeters are included for manual monitoring. A 24V DC power supply unit ensures a steady and isolated control voltage to power the PLC and associated components.



International Journal of Innovative Research of Science, Engineering and Technology (IJIRSET)



www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 5, May 2025

|DOI: 10.15680/IJIRSET.2025.1405250|



Fig5.1: WORKING MODEL

5.1 Fault Scenarios

The following fault types are simulated:

- Overcurrent due to mechanical overload

- Under voltage and Over voltage
- Phase loss from cable disconnection
- Overtemperature from poor ventilation

Each condition is tested and the PLC response is logged.

VI. RESULT AND DISCUSSION

The proposed system reliably detected faults in all tested scenarios. Response times were within acceptable industrial standards (under 200ms). The Delta PLC effectively coordinated sensor input with logical control outputs, demonstrating the feasibility of using PLCs for motor protection. Graphs and data tables illustrate system performance.

VII. FUTURE PROSPECTS

The current implementation provides an efficient solution for basic motor fault detection and protection. However, further developments can significantly enhance system capabilities and adaptability.

One such improvement is the integration with SCADA or HMI systems for graphical monitoring, remote control, and data logging. This would allow operators to analyse motor performance over time and make informed decisions.

Another enhancement is the addition of GSM or IoT modules to send real-time fault alerts via SMS or app notifications to maintenance personnel.

Predictive maintenance can also be implemented by analysing sensor data trends, helping to anticipate faults before they occur and schedule preventive service.

Energy monitoring tools can be incorporated to study power usage and implement load balancing strategies, improving overall energy efficiency.

Finally, the system can be adapted for multiple motors or different types of machinery with minimal changes to the software and hardware, increasing its industrial relevance.



International Journal of Innovative Research of Science, Engineering and Technology (IJIRSET)



www.ijirset.com |A Monthly, Peer Reviewed & Refereed Journal| e-ISSN: 2319-8753| p-ISSN: 2347-6710|

Volume 14, Issue 5, May 2025

|DOI: 10.15680/IJIRSET.2025.1405250|

VIII. RECOMMENDATIONS

To ensure optimal performance and reliability, certain practices should be followed during and after installation:

- Shielded cables should be used for sensor signals to avoid electrical noise and false triggering.
- All sensors and relays must be calibrated regularly to maintain accuracy.
- Operators should be trained to understand the alarms, reset mechanisms, and basic fault diagnosis procedures.
- Backup copies of the PLC program should be stored securely for easy restoration in case of failure or corruption.
- Periodic testing of the system should be performed under simulated fault conditions to verify system response and make necessary updates.

IX. CONCLUSION

The integration of PLCs into induction motor protection systems significantly enhances fault detection capabilities. The proposed system ensures motor longevity and operational safety while maintaining flexibility and ease of deployment. Future work may explore integration with SCADA systems for remote monitoring and diagnostics.

The implementation of a PLC-based fault detection and protection system using the Delta DVP series provides a robust and intelligent solution for safeguarding three-phase induction motors. The system demonstrates real-time fault monitoring, fast protective action, and effective user alerts, which together enhance system safety and motor longevity. Its modular, programmable, and expandable nature makes it suitable for various industrial environments. The integration of such automation in motor protection not only reduces maintenance costs but also ensures continuous, uninterrupted industrial operations.

REFERENCES

- 1. Ramesh, K., & Kumar, R. (2019). Design and Implementation of Microcontroller-Based Protection System for Induction Motors. International Journal of Electrical Engineering & Technology (IJEET), 10(2), 27–35.
- Roy, S., & Saha, P. (2021). PLC Based Protection of Irrigation Pump Motors. International Journal of Engineering Research & Technology (IJERT), 10(5), 1–5.
- 3. Delta Electronics. (2020). Delta DVP Series PLC Programming Manual. [Online] Available: https://www.deltaww.com
- 4. Bhattacharya, S., & Majumdar, S. (2020). A Review on Fault Diagnosis of Induction Motor. International Journal of Emerging Technologies in Engineering Research (IJETER), 8(4), 18–23.
- 5. Saini, A., & Goyal, R. (2018). PLC Based Industrial Motor Protection Using Real-Time Sensors. International Journal of Innovative Research in Science, Engineering and Technology (IJIRSET), 7(3), 1420–1425.
- 6. Pattanayak, A., & Mishra, M. (2017). Modern Techniques in Induction Motor Fault Diagnosis. International Journal of Electrical and Electronics Research, 5(2), 198–202.
- 7. IEEE Industrial Electronics Society. (2022). Fault Detection and Isolation in Industrial Motor Systems. IEEE Transactions on Industrial Electronics.
- 8. Sharma, M., & Gupta, N. (2020). Temperature Monitoring and Control of Induction Motor Using PLC and SCADA. International Journal of Control and Automation, 13(2), 89–94.
- 9. Khan, M. A., & Usmani, M. A. (2016). PLC Based Automation of Motor Protection and Control. International Journal of Engineering and Technology, 5(5), 439–443.
- 10. Delta Electronics. (2021). DVP-PLC Application Guide for Motor Control and Protection. Technical Documentation. [Online] Available: https://www.deltaww.com/en-US/products/Automation









INTERNATIONAL JOURNAL OF INNOVATIVE RESEARCH

IN SCIENCE | ENGINEERING | TECHNOLOGY





www.ijirset.com