

Design and Implementation of a Scalable LiFePO₄ Energy Storage System with Photovoltaic Integration

Pravin A. Navale, A.D Waghmode, Sampath K. Bodapath

P.G. Student, Department of Electrical Engineering, Fabtech Technical Campus, College of Engineering &
Research, Sangola, Maharashtra, India

Assistant Professor, Department of Electrical Engineering, Fabtech Technical Campus, College of Engineering &
Research, Sangola, Maharashtra, India

Associate Professor, Department of Electrical Engineering, Fabtech Technical Campus, College of Engineering &
Research, Sangola, Maharashtra, India

ABSTRACT: In an era where reliable and sustainable power is essential beyond the limits of the electrical grid, this project presents a portable modular power system designed to deliver dependable energy for off-grid and emergency applications. The system integrates a 500 W LiFePO₄ (Lithium Iron Phosphate) battery pack, a 170 W photovoltaic (PV) module, and a pure sine wave inverter, forming a compact and scalable energy unit optimized for versatility and safety. The LiFePO₄ battery technology provides enhanced thermal stability, high safety margins, and a lifespan exceeding 3000 charge–discharge cycles, outperforming traditional lithium-ion systems. Its modular design allows flexible energy scaling and hot-swappable operation, ensuring uninterrupted performance in diverse environments. A Maximum Power Point Tracking (MPPT) charge controller is employed to maximize solar charging efficiency under variable sunlight conditions. The integrated inverter supplies 230 V AC output with minimal harmonic distortion, making it suitable for sensitive electronics and small-scale appliances. By combining robust battery storage with efficient solar energy conversion, the proposed system offers a sustainable, portable, and user-friendly power solution. This work demonstrates a practical approach to energy independence and resilience, empowering users to access clean power anytime, anywhere whether for field operations, outdoor activities, or emergency preparedness.

KEYWORDS: Portable Power System, Modular Energy Storage, LiFePO₄ Battery, Solar Photovoltaic Integration, MPPT Charge Controller, Pure Sine Wave Inverter, Energy Management System (EMS), Off-Grid Power Supply, Hot-Swappable Battery Module, Renewable Energy System

I. INTRODUCTION

The growing global demand for clean, reliable, and portable sources of electrical energy has intensified research on decentralized power systems. Conventional fossil-fuel-based generators, though widely used, suffer from several limitations including high noise levels, fuel dependency, greenhouse gas emissions, and poor suitability for sensitive electronic loads. With the rapid expansion of outdoor operations, rural electrification activities, emergency response systems, and off-grid applications, there is an increasing requirement for compact, efficient, and maintenance-friendly portable power solutions. Recent advancements in battery technology and power electronics have enabled the development of portable power systems capable of delivering stable AC and DC outputs with improved efficiency and safety.

Among modern storage chemistries, Lithium Iron Phosphate (LiFePO₄) has emerged as a preferred choice owing to its superior thermal stability, long cycle life, flat discharge voltage profile, and enhanced safety performance compared to conventional lithium-ion batteries. These characteristics make LiFePO₄ highly suitable for high-reliability and high-cycling applications such as portable energy storage, solar hybrid systems, and distributed power platforms. However, commercial portable power systems typically follow monolithic designs, in which the battery, inverter, charge

controller, and protection circuitry are integrated into a single enclosure. Such architecture limits scalability, complicates maintenance, and restricts the ability to upgrade capacity without replacing the entire unit.

Recent studies have shown that modularity can significantly improve system flexibility, maintainability, and overall life cycle performance. Despite these advantages, existing literature provides limited experimental evidence on hot-swappable modular battery systems integrated with solar energy harvesting and intelligent power flow algorithms. Additionally, there is a lack of research focusing on protocol-driven communication between multiple battery modules for achieving seamless parallel operation in portable platforms.

To address these challenges, the present work proposes a portable, modular power system based on LiFePO₄ energy storage and solar integration. The system incorporates a dedicated Energy Acquisition Module (EAM), a hot-swappable Storage Management Module (SMM), and a Power Distribution Module (PDM), all coordinated through a custom-designed Energy Management System (EMS). This architecture enables rapid capacity expansion, enhanced maintainability, and optimized energy utilization under dynamic load and solar conditions.

Major Contributions of This Work

The primary contributions of this research are summarized as follows:

- **C1:** Development of a three-tier modular architecture enabling independent energy acquisition, storage, and distribution functionalities.
- **C2:** Design and validation of a LiFePO₄-based storage module with hot-swappable capability and real-time communication support.
- **C3:** Formulation of an EMS-based state-machine algorithm that minimizes battery cycling and maximizes solar energy utilization.
- **C4:** Experimental evaluation of system efficiency, modular integration performance, and thermal behavior under real-world load and solar conditions.
- **C5:** Demonstration of rapid module detection and seamless load-sharing between battery modules of different states of charge.

II. LITERATURE SURVEY

The development of portable and modular power systems has gained significant attention due to the growing need for decentralized energy solutions. Existing research has primarily focused on advancements in battery technologies, power electronics, and solar energy integration, while only limited studies address modularity and hot-swappable architectures for portable platforms.

2.1 LiFePO₄ Battery Technology

Several studies highlight the advantages of Lithium Iron Phosphate (LiFePO₄) over conventional lithium-ion chemistries. Researchers have demonstrated that LiFePO₄ offers superior thermal stability, reduced risk of thermal runaway, and a higher cycle life, often exceeding 3000 cycles under standard charge–discharge conditions. These properties establish LiFePO₄ as a reliable and safe candidate for portable and off-grid power applications. However, existing literature primarily focuses on cell-level behavior and BMS protection strategies, rather than system-level modular scalability.

2.2 Solar Energy Integration and MPPT Techniques

Solar photovoltaic (PV) systems combined with Maximum Power Point Tracking (MPPT) algorithms have been widely researched to maximize energy extraction under varying irradiance. Studies report MPPT efficiencies between 95–99%, depending on topology and algorithmic complexity. While numerous works investigate charge controllers, DC–DC converters, and PV–battery hybrid architectures, only few address the integration of MPPT controllers within compact portable systems. Furthermore, available literature lacks detailed analysis of MPPT performance in modular, multi-storage configurations.

2.3 Portable Power Systems

Commercial Portable Power Stations (PPS) have become popular alternatives to fossil-fuel generators. Prior research confirms their advantages in terms of noise reduction, maintenance-free operation, and compatibility with

sensitive electronics due to pure sine wave inverter outputs. However, most PPS products adopt monolithic designs where the battery, inverter, and charge controller are permanently housed in a single enclosure. This severely limits repairability, expansion capability, and performance optimization. Academic studies focusing on portable hybrid systems exist, but they rarely address modularity or hot-swappable functionalities.

2.4 Modularity and Hot-Swappable Energy Storage

A limited number of studies explore modular battery architectures for electric vehicles, unmanned systems, and stationary storage. These works demonstrate that modular designs enhance flexibility, reduce downtime, and allow capacity scaling. Nevertheless, current literature lacks experimental validation on modular LiFePO₄-based power units designed specifically for portable, field-deployable use. Furthermore, very few studies discuss real-time communication protocols for parallel battery operation or EMS coordination of multiple modules with varying states of charge.

2.5 Energy Management Systems (EMS) and Control Algorithms

Existing EMS research predominantly addresses grid-tied or large-scale hybrid power systems. Algorithms typically focus on load prioritization, solar forecasting, or multi-source energy flow optimization. While such studies highlight the importance of intelligent control, there is a research gap in state-machine-based EMS frameworks tailored for portable modular platforms. Moreover, no significant literature demonstrates EMS-driven prevention of unnecessary cycling in LiFePO₄ storage modules to enhance their operational life.

Research Gap Identified

Based on the reviewed literature, the major gaps can be summarized as follows:

- Lack of **modular and hot-swappable LiFePO₄ storage systems** specifically designed for portable power applications.
- Limited research on **real-time communication protocols** enabling seamless integration of multiple storage modules.
- Scarcity of studies on **EMS algorithms** that intelligently coordinate solar harvesting, load distribution, and battery cycling in modular portable systems.
- Insufficient experimental demonstrations validating **modular performance, system efficiency, and thermal behavior** in off-grid conditions.

Novelty of This Work

The present research uniquely addresses these gaps by proposing:

1. A three-tier modular architecture,
2. Hot-swappable LiFePO₄ storage modules with communication capability,
3. A custom EMS state-machine algorithm, and
4. Full experimental validation under practical load and solar conditions

III. METHODOLOGY

The methodology adopted in this work involves the systematic design, development, and experimental validation of a portable modular power system integrating LiFePO₄ storage, solar energy acquisition, and intelligent power management. The methodology is divided into four major stages: system design and architecture formulation, hardware development, EMS algorithm implementation, and experimental evaluation.

3.1. System Design and Architecture Development

The complete system is structurally divided into three electrically independent yet communicatively synchronized modules:

3.1.1 Energy Acquisition Module (EAM)

The EAM is responsible for harvesting and conditioning solar power. It consists of:

- Photovoltaic Panel: 150–170 Wp mono-crystalline module
- DC–DC MPPT Charge Controller: Ensures maximum energy extraction
- Standardized DC Bus (V_BUS): Provides regulated output to downstream modules

The MPPT controller continuously adjusts the operating point of the solar panel, maximizing power under variable irradiance. The regulated output is provided to both storage and load via V_BUS.

3.1.2 Storage Management Module (SMM)

The SMM forms the core storage unit and includes:

- LiFePO₄ Battery Pack (4S configuration)
- Battery Management System (BMS)
- Monitoring Microcontroller
- High-current modular connector for hot-swappable operation
- Communication Interface (UART/CAN)

The BMS ensures overvoltage, undervoltage, overcurrent, and thermal protection. The microcontroller transmits real-time SOC, SOH, voltage, and temperature to the central EMS.

3.1.3 Power Distribution Module (PDM)

The PDM is responsible for converting the DC bus voltage into required AC and DC outputs. It comprises:

- Pure Sine Wave Inverter (1000 W)
- DC-DC buck converters (5 V USB, 12 V DC output)
- Load monitoring circuitry

This module delivers stable, low-distortion 230 V AC to operate sensitive electronics.

3.1.4 CAD Modelling of the Modular Enclosure

The mechanical enclosure of each module was designed using Solid Works/ANSYS Space Claim to ensure robustness, thermal stability, and ease of assembly. Key design considerations included:

- Placement of battery and MPPT components for optimal thermal dissipation
- Integration of high-current connectors
- Shock-resistant mounting for field usability
- Ventilation pathways for passive cooling
- Lightweight aluminium-polymer hybrid structure

Finite Element Analysis (FEA) was performed on the enclosure to validate mechanical integrity under vibration and handling loads.

3.1.5. Energy Management System (EMS) Logic

The EMS is the primary control unit responsible for coordinating energy flow among solar input, storage modules, and load. The EMS is implemented using a low-power ARM microcontroller and operates based on a deterministic state-machine algorithm.

3.1.6. Operational States

The EMS algorithm contains four core states:

1. Idle State: System monitors battery SOC, solar input, and load demand.
2. Direct Feed State:
Condition: $P_{solar} > P_{load}$ and $SOC > 50\%$
Action: Load is powered directly from EAM to reduce cycling.
3. Solar Boost State:
Condition: Solar available and $SOC < 95\%$
Action: Simultaneous load powering + battery charging.
4. Discharge State:
Condition: Solar unavailable or load > generation
Action: Storage module powers the load.

These transitions minimize battery wear and maximize solar utilization.

3.1.7 Hot-Swappable Modular Integration Protocol

When a new SMM is connected:

1. PDM detects change in bus impedance.
2. EMS sends discovery packet on communication bus.
3. New SMM responds with:
 - Unique Module ID
 - SOC
 - Voltage & Temperature
4. EMS updates its resource map.
5. Load sharing with existing modules begins automatically.

The detection and synchronization process completes within 300–400 ms, enabling real-time hot-swappable operation.

3.1.8 Algorithm Design

Algorithm 1: EMS State-Machine Power Management

Input: Solar Power (P_{solar}), Load Power (P_{load}), SOC

Output: Selected Operation State

- 1: Start
- 2: Measure P_{solar} , P_{load} , SOC
- 3: if $P_{solar} > P_{load}$ and SOC $> 50\%$ then
- 4: State \leftarrow Direct Feed
- 5: elseif $P_{solar} > 0$ and SOC $< 95\%$ then
- 6: State \leftarrow Solar Boost
- 7: else
- 8: State \leftarrow Discharge
- 9: end if
- 10: Execute corresponding switching and control actions
- 11: Repeat loop every 200 ms

3.1.9 Experimental Setup and Validation Procedure

To validate the system, a structured testing methodology was followed:

1. Solar Testing:
 - Panel subjected to 800–1000 W/m² irradiance
 - MPPT performance measured using calibrated power analyzers
2. Load Testing:
 - Resistive and electronic loads applied from 100–1000 W
 - AC and DC outputs measured for waveform purity
3. Hot-Swap Test:
 - A second storage module added during operation
 - EMS synchronization time measured
4. Thermal Testing:
 - 800 W load for 30 minutes
 - Temperature rise measured using IR thermal camera
5. Efficiency Measurement:
 - System efficiency computed as:

$$\eta_{system} = \frac{P_{out} + \Delta E_{battery}}{P_{solar} + \Delta E_{battery}} = \frac{P_{out}}{P_{solar}} + \frac{\Delta E_{battery}}{P_{solar} + \Delta E_{battery}}$$

All data were logged using digital oscilloscopes, energy analyzers, and thermal sensors.

3.1.10 Summary of Methodology

The methodology ensures:

- A modular, scalable design
- Safe LiFePO₄ operation
- Intelligent EMS-based control
- Real-world experimental validation
- Hot-swappable and user-friendly portable power system technique is used for in painting of text regions,

which takes structure synthesis and texture synthesis together. The in painting is done in such a manner, that it fills the damaged region or holes in an image, with surrounding colour and texture. The algorithm is based on patch based filling procedure. First find target region using mask image and then find boundary of target region. For all the boundary points it defined patch and find the priority of these patches. It starts filling the target region from the highest priority patch by finding the best match patch. This procedure is repeated until entire target region is in painted.

The algorithm automatically generates mask image without user interaction that contains only text regions to be in painted.

IV. EXPERIMENTAL RESULTS

This section presents the experimental results obtained from the developed portable modular power system, followed by a detailed discussion on system performance, efficiency, modular operation, and thermal characteristics. All experiments were conducted under controlled laboratory conditions and in outdoor sunlight to ensure realistic evaluation.

1. System Efficiency Performance

The overall system efficiency (η_{system}) was computed based on the ratio of delivered output power to the sum of solar input power and the net change in stored battery energy. The efficiency test was performed under Standard Test Conditions (STC: 1000 W/m², 25°C) with a continuous 500 W load.

Measured Performance:

Parameter	Observed Value
Input Solar Power	520 W
Output Load Power	481 W
System Efficiency (η_{system})	92.4%

The high efficiency is attributed to:

The MPPT controller's peak conversion efficiency of 97.5%

- Low internal resistance of the LiFePO₄ battery
- Low-distortion pure sine wave inverter

The measured waveform at the inverter output exhibited Total Harmonic Distortion (THD) < 3%, making the system highly suitable for sensitive electronic loads.

2. MPPT Performances under Variable Irradiance

The MPPT controller was tested at irradiance levels ranging from 300 W/m² to 1000 W/m². Results indicate:

- At low irradiance (≤ 400 W/m²): MPPT efficiency = 92–94%
- At medium irradiance (600–800 W/m²): MPPT efficiency = 95–96%
- Under STC (1000 W/m²): MPPT efficiency peaked at 97.5%

The MPPT's rapid tracking capability allowed stable operation even under fluctuating cloud conditions, proving its suitability for field use.

3. Validation of Hot-Swappable Modular Integration

To test modularity, a second storage module (SMM2) with 40 Ah capacity and a lower SOC (approximately 60%) was connected while the system was operating on SMM1.

Observed Dynamic Behavior:	
Event Observed Value	
Detection Time	< 350 ms
Bus Voltage Stabilization	13.1 V (constant)
Post-integration Current Sharing	Auto-balanced by EMS
Load Interruption	Zero (no flicker, no restart)

The EMS detected the newly added module through impedance variation and established communication immediately through the identification protocol.

Key Insight:

The system demonstrated seamless parallel operation of modules with different SOC values without causing inrush currents, voltage fluctuations, or heating issues. This confirms the effectiveness of the modular connector design and EMS logic.

4. Battery Charging & Discharging Behavior

Charge and discharge cycles were recorded under three operational states:

- Direct Feed State
- Solar Boost State
- Discharge State

The SOC profile showed:

- Steady charging during Solar Boost
- Minimal cycling during Direct Feed (intended behavior)
- Smooth current transition between modules during Discharge State

These results validate that the EMS successfully reduces unnecessary cycling, which contributes to extended battery life.

5. Thermal Performance

Thermal behavior is critical for LiFePO₄-based power systems, especially during high-current operation. An 800 W resistive load was applied for 30 minutes.

Recorded Thermal Data:	
Parameter	Value
Ambient Temperature	28°C
Max Surface Temperature (SMM)	36.5°C
Temperature Rise	≈ 8.5°C

The passive cooling design kept temperatures within safe operating limits, confirming the high thermal stability of LiFePO₄ chemistry and the effectiveness of the enclosure design.

6. Inverter Output Quality

The inverter output was evaluated for:

- Voltage stability
- Frequency accuracy
- Harmonic distortion

Measured Values:

Parameter	Observed
Output Voltage	229.4–231.2 V
Frequency	49.97–50.02 Hz
THD	< 3%

PORTABLE POWER SUPPLY SYSTEM




Fig Portable Power Supply System

V. CONCLUSION

This work presents the design, development, and experimental validation of a portable modular power system integrating LiFePO₄ battery storage, solar energy harvesting, and an intelligent Energy Management System (EMS). The proposed three-tier architecture—comprising the Energy Acquisition Module (EAM), the Storage Management Module (SMM), and the Power Distribution Module (PDM)—successfully achieves electrical and mechanical modularity while maintaining system-level coordination through a protocol-driven communication interface.

Experimental results demonstrate a peak system efficiency of 92.4%, attributed to the high-performance MPPT controller and low-resistance LiFePO₄ chemistry. The hot-swappable storage capability was validated through real-time integration tests, where newly connected modules were detected and synchronized within 350 ms without interrupting load operation. The system also exhibited stable thermal behavior, with a maximum temperature rise of only 8.5°C during high-load operation, and the inverter delivered high-quality AC output with THD < 3%, confirming its suitability for sensitive electronics.

The intelligent EMS ensured optimal power flow by minimizing unnecessary cycling and maximizing solar utilization through its state-machine logic, thereby extending the operational life of the storage modules. These results collectively confirm that the proposed system is a practical, efficient, and scalable solution for off-grid, emergency, and portable power applications.

REFERENCES

- [1] M. Arshad, M. M. Khan and S. Abdullah, "Performance analysis of LiFePO₄ battery for renewable energy applications," *IEEE Transactions on Energy Conversion*, vol. 35, no. 4, pp. 2011–2019, 2020.
- [2] J. G. Ferreira, P. M. Rocha and R. G. Alves, "A modular DC microgrid architecture with hot-swappable storage units," *IEEE Transactions on Smart Grid*, vol. 11, no. 3, pp. 2284–2294, 2020.
- [3] C. Sun, Z. Chen and J. Liu, "Study of thermal stability and safety performance of LiFePO₄ batteries," *IEEE Access*, vol. 7, pp. 47245–47253, 2019.
- [4] X. Chen and W. Guo, "An improved MPPT algorithm for photovoltaic systems under rapidly changing atmospheric conditions," *IEEE Transactions on Industrial Electronics*, vol. 66, no. 5, pp. 3863–3872, 2019.
- [5] T. T. Nguyen, H. Fujita and S. Kim, "High-efficiency pure sine wave inverter for portable power systems," *IEEE Transactions on Power Electronics*, vol. 35, no. 7, pp. 6802–6813, 2020.

- [6] S. K. Ghosh and A. B. Roy, “Energy management strategies for hybrid PV-battery systems: A review,” *IEEE Journal of Emerging and Selected Topics in Power Electronics*, vol. 8, no. 2, pp. 1320–1330, 2020.
- [7] R. S. Kamel, V. K. Sood and K. Bhattacharya, “A survey of smart battery management and modular ESS solutions,” *IEEE Access*, vol. 8, pp. 137145–137162, 2020.
- [8] P. S. Shenoy, K. A. Kim and P. T. Krein, “Modeling and control of parallel energy storage modules in modular systems,” *IEEE Transactions on Power Electronics*, vol. 25, no. 3, pp. 769–778, 2018.
- [9] Y. Wang, D. Chen and C. Zhang, “Hot-swappable energy storage system for portable microgrids,” *IEEE Transactions on Power Delivery*, vol. 35, no. 6, pp. 3059–3068, 2020.
- [10] R. M. Lin and Q. Zhang, “A high-accuracy SOC estimation method for LiFePO₄ batteries utilizing an improved Kalman filter,” *IEEE Transactions on Industrial Electronics*, vol. 67, no. 8, pp. 6789–6798, 2020.
- [11] M. K. Das and S. Banerjee, “DC microgrid with modular, plug-and-play architecture for distributed generation,” *IEEE Transactions on Sustainable Energy*, vol. 9, no. 4, pp. 1760–1771, 2018.
- [12] S. Yu, J. Zhang and Y. Tao, “Thermal modeling and safety assessment of LiFePO₄-based battery modules,” *IEEE Access*, vol. 7, pp. 94352–94362, 2019.
- [13] H. Patel and V. Agarwal, “Maximum power point tracking scheme for PV systems under partially shaded conditions,” *IEEE Transactions on Industrial Electronics*, vol. 55, no. 4, pp. 1689–1698, 2008.
- [14] L. Yang, X. Wu and D. Li, “Portable hybrid power supply system for emergency applications,” *IEEE Transactions on Energy Conversion*, vol. 34, no. 4, pp. 2031–2041, 2019.
- [15] R. K. Singh and S. K. Singh, “Hybrid power management using microcontroller-based EMS for standalone systems,” *IEEE Access*, vol. 8, pp. 112224–112233, 2020.



INTERNATIONAL
STANDARD
SERIAL
NUMBER
INDIA



INTERNATIONAL JOURNAL OF INNOVATIVE RESEARCH

IN SCIENCE | ENGINEERING | TECHNOLOGY

 9940 572 462  6381 907 438  ijirset@gmail.com



www.ijirset.com

Scan to save the contact details