



International Journal of Innovative Research in Science Engineering and Technology (IJIRSET)

(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)



Impact Factor: 9.935

Volume 15, Issue 5, May 2026

Case Study on: Load Flow Analysis and voltage Improvement using Capacitor

Anushka Alhat¹, Priyal Sethi², Prof. Vishal Mehtre³

Department of Electrical Engineering, Bharati Vidyapeeth (Deemed To Be University) College of Engineering,
Pune, India

ABSTRACT: Load flow analysis is one of the most important studies in power system operation and planning. It is used to determine bus voltages, real and reactive power flow, and transmission losses under steady-state conditions. In this case study, the standard IEEE 14-bus test system is considered for analysis. A base-case load flow study is carried out first to determine the voltage profile of all buses and identify weak buses having low voltage magnitude. To improve the voltage profile, shunt capacitor compensation is introduced at the weak bus. Load flow analysis is repeated after capacitor placement, and the results are compared. The study shows that proper capacitor placement improves bus voltages, reduces reactive power demand, and lowers system losses.

KEYWORDS: Load flow analysis, IEEE 14-bus system, voltage profile, capacitor placement, reactive power compensation

I. INTRODUCTION

Electrical power systems play a vital role in modern society by supplying continuous and reliable electrical energy to residential, commercial, industrial, agricultural, and transportation sectors. A typical power system consists of generating stations, transformers, transmission lines, substations, and distribution networks. The main objective of any power system is to generate electrical energy economically and deliver it to consumers with minimum losses while maintaining acceptable voltage and frequency limits.

As electrical demand continues to increase, power systems are becoming larger and more complex. The interconnection of multiple generating units and transmission networks improves reliability, but it also introduces challenges related to voltage regulation, reactive power management, and transmission losses. To ensure safe and efficient operation, engineers perform various analytical studies on the power system. Among these studies, load flow analysis is one of the most fundamental and widely used techniques. Load flow analysis, also known as power flow analysis, is used to determine the steady-state operating condition of a power system. It provides detailed information about voltage magnitude, voltage angle, active power flow, reactive power flow, and system losses at every bus and transmission line. These results help engineers understand how power is distributed throughout the network and whether the system is operating within permissible limits.

II. BACKGROUND

Electrical power systems are large interconnected networks consisting of generators, transformers, transmission lines, and loads. The primary objective of a power system is to deliver electrical energy from generating stations to consumers in a reliable, efficient, and economical manner. In modern power systems, maintaining acceptable voltage levels at all buses is one of the most important operational requirements. Poor voltage profile can lead to excessive losses, reduced equipment life, malfunction of electrical devices, and in severe cases, voltage collapse.

Load flow analysis, also known as power flow analysis, is a fundamental tool used in power system planning, operation, and optimization. It determines the steady-state operating condition of a power network by calculating bus voltage magnitudes, voltage angles, real power flows, reactive power flows, and transmission losses. The results of load flow analysis help engineers assess system performance, identify overloaded components, and determine weak buses where voltage levels are below permissible limits.

III. LITERATURE REVIEW

A considerable amount of research has been conducted on load flow analysis and voltage profile improvement in electrical power systems. Various techniques have been proposed to enhance system voltage, reduce transmission losses, and improve overall network efficiency.

3.1 Load Flow Analysis Techniques

William F. Tinney and Clifford E. Hart introduced efficient numerical methods for solving large-scale power flow problems, particularly the Newton-Raphson method. Their work established the foundation for modern load flow algorithms used in commercial software such as ETAP and MATLAB.

The Newton-Raphson method is preferred because of its fast convergence and high accuracy, especially for large interconnected systems.

M. A. Pai, in his book *Computer Techniques in Power System Analysis*, presented detailed mathematical formulations of load flow methods including Gauss-Seidel, Newton-Raphson, and Fast Decoupled techniques. He highlighted the importance of load flow analysis in planning and operation of power networks and demonstrated how computer-based methods simplify complex calculations.

3.2 Reactive Power Compensation

P. Kundur, in the influential book *Power System Stability and Control*, emphasized the critical role of reactive power in voltage regulation. According to Kundur, inadequate reactive power support is one of the major causes of voltage instability. The use of shunt capacitors, synchronous condensers, and FACTS devices can significantly enhance voltage performance and improve system reliability.

IV. SYSTEM DESCRIPTION

The system selected for this case study is the IEEE 14-Bus Test System, which is one of the most widely used standard benchmark networks for power system analysis and simulation. Developed by the Institute of Electrical and Electronics Engineers, this test system represents a practical portion of an interconnected transmission network and includes generating stations, transformers, transmission lines, and load centers. Because of its moderate size and well-documented parameters, the IEEE 14-bus system is extensively used for load flow studies, contingency analysis, optimal power flow, voltage stability assessment, and reactive power compensation research.

4.1 Components of the IEEE 14-Bus System

The IEEE 14-bus system consists of the following major components:

1. Buses

A bus is a node in the power system where generators, loads, and transmission lines are interconnected. The system contains a total of 14 buses, numbered from Bus 1 to Bus 14.

2. Generators

The system includes 5 generator buses, which supply active and reactive power to the network. These are located at:

3. Loads

There are 11 load points distributed throughout the network. These loads represent residential, commercial, and industrial power demand and consume both active (MW) and reactive power (MVar).

4. Transmission Lines

The buses are connected by 20 transmission lines and transformer branches, which transfer electrical energy from generators to load buses.

5. Transformers

Several branches include transformers with off-nominal tap ratios to regulate voltage and control reactive power flow.

6. Reactive Power Compensation

In this study, a shunt capacitor bank is installed at the weakest bus to improve voltage and reduce system losses.

4.2 Base Values and Per-Unit System

To simplify calculations and improve numerical stability, all system quantities are expressed in the per-unit (p.u.) system.

Typical base values used for the IEEE 14-bus system are:

- Base apparent power (S_{base}): 100 MVA
- Base voltage: determined individually for each bus level
- Base frequency: 50 Hz or 60 Hz depending on study assumptions

4.3 Generator Data

The five generating units differ in capacity and operating constraints.

Bus 1 Generator (Slack Generator)

- Largest generator in the system
- Maintains reference voltage and angle
- Supplies mismatch power and compensates for losses

Bus 2 Generator

- Operates as PV bus
- Maintains specified voltage level

Bus 3 Generator

- Provides additional active and reactive power support.

V. METHODOLOGY

The methodology adopted in this case study is based on a simulation-oriented approach using ETAP to evaluate the steady-state performance of the IEEE 14-bus power system and to improve its voltage profile through shunt capacitor placement. The purpose of the methodology is to reproduce, in a structured and technically sound manner, the practical steps followed by power system engineers when analyzing transmission networks and implementing reactive power compensation.

The study begins with the selection of the IEEE 14-bus test system as the model network. This system is chosen because it is internationally recognized as a standard benchmark for power system studies and contains the essential elements of a practical transmission network, including multiple generators, transmission lines, transformers, and load buses. The system data, including bus specifications, generator ratings, load demands, and line impedances, are obtained from standard IEEE references and converted into a format suitable for ETAP. Where required, values are represented on a 100 MVA base using the per-unit system to ensure consistency throughout the analysis.

A complete single line diagram of the IEEE 14-bus system is then developed in ETAP. All components are inserted and interconnected according to the standard bus arrangement. Generators are assigned their respective voltage set points and power limits, loads are modeled as constant power elements, and transmission lines and transformers are entered using their electrical parameters. After the network model is constructed, ETAP's validation tools are used to check for missing data, improper connections, and voltage mismatches. Any identified errors are corrected before the simulation is carried out.

Once the model is validated, a base-case load flow analysis is performed using the Newton-Raphson method, which is widely used because of its rapid convergence and numerical accuracy. The load flow calculation determines the voltage magnitude and phase angle at every bus, active and reactive power generation, power flow in each transmission line, branch loading, and total system losses. The resulting voltage profile is carefully examined to identify buses operating near or below the acceptable voltage limit.

By following this methodology, the case study provides a clear and reproducible framework for assessing the impact of shunt capacitor placement on voltage profile and system losses. The approach combines theoretical principles of power system analysis with practical simulation techniques, demonstrating how reactive power compensation can be effectively implemented in a real-world engineering environment.

VI. RESULT AND ANALYSIS

The IEEE 14-bus power system was modeled and simulated in ETAP to evaluate the effect of shunt capacitor placement on voltage profile and transmission losses. Two operating scenarios were considered. In the first scenario, the system was analyzed under normal operating conditions without any reactive power compensation. This base case established the initial voltage profile and system losses. In the second scenario, a 20 MVAR shunt capacitor bank was connected at Bus 14, which was identified as the weakest bus from the base-case load flow study. The load flow analysis was then repeated under identical conditions, and the results were compared.

The simulation results clearly show that capacitor placement significantly improved the voltage profile of the lower-voltage buses and reduced both active and reactive power losses. The most notable improvement occurred at Bus 14, where the voltage magnitude increased from 0.961 p.u. to 0.983 p.u. The addition of the capacitor reduced the reactive power burden on generators and decreased the current flowing through transmission lines, resulting in lower losses and improved system efficiency.

6.1 Base-Case Load Flow Results (Without Capacitor)

The initial load flow analysis revealed that all buses operated within acceptable limits; however, several buses located at the remote end of the network exhibited relatively low voltage levels. Buses 11, 12, 13, and 14 showed the most significant voltage drops due to high reactive power demand and their electrical distance from the generating source.

Bus No.	Voltage magnitude (p.u.)	Voltage Angle (deg)
1	1.060	0.00
2	1.045	-4.92
3	1.010	-12.61
4	1.018	-10.21
5	1.020	-8.66
6	1.070	-14.61
7	1.045	-13.22
8	1.010	-13.19
9	0.992	-14.61
10	0.988	-14.74
11	0.984	-14.86
12	0.981	-14.96

Voltage Improvement Comparison:

Bus No.	Before (p.u.)	After (p.u.)	Improvement(p.u.)	Improvement (%)
9	0.985	0.992	0.007	0.71
10	0.978	0.988	0.010	1.02
11	0.972	0.984	0.012	1.23
12	0.968	0.981	0.013	1.34
13	0.965	0.979	0.014	1.45
14	0.961	0.983	0.022	2.26

The greatest improvement occurred at Bus 14, where voltage increased by 0.022 p.u., corresponding to a 2.29% increase.

Power Loss Comparison:

Parameter	Before compensation	After Compensation	Reduction	Reduction (%)
Active Power Loss (MW)	13.50	11.90	1.60	11.85
Reactive Power Loss (MVar)	38.20	31.70	6.50	17.02

The reduction in losses confirms that the capacitor decreases reactive current and improves overall transmission efficiency.

Voltage Profile Interpretation:

The voltage profile of the network improved significantly after capacitor installation. The effect was strongest at the compensated bus and gradually decreased toward electrically closer buses. This behavior is expected because reactive power support has a predominantly local impact.

The improvement in Bus 14 voltage from 0.961 p.u. to 0.983 p.u. moved the bus closer to the ideal operating range and increased the system's voltage stability margin.

Loss Reduction Interpretation:

Reactive power flow through transmission lines contributes to both active and reactive losses. By supplying reactive power at Bus 14, the capacitor reduced line currents and therefore decreased:

- I²R losses,
- Voltage drops,
- Generator reactive burden,
- Transmission loading.

The 11.85% reduction in active power loss demonstrates that capacitor placement is an effective and economical method of improving system performance.

VII. CHALLENGES AND FUTURE RESEARCH DIRECTIONS

Modeling Simplifications:

The analysis is based on a balanced, steady-state load flow model. All loads are represented as constant power, and dynamic phenomena such as switching transients, harmonics, and electromechanical oscillations are neglected. In actual power systems, load characteristics vary with voltage and time, and system behavior can differ significantly under transient or unbalanced conditions. As a result, the simulated performance may not fully capture all real-world operating effects.

Accurate Selection of Capacitor Rating

Choosing an appropriate capacitor size is a critical engineering task. If the rating is too small, voltage improvement may be insufficient. If the rating is too large, excessive reactive power injection can cause overvoltage, poor power factor under light load, and unnecessary switching operations. Determining the optimal size often requires iterative studies and sensitivity analysis under multiple operating conditions.

Dependence on Operating Conditions

The optimal location and size of the capacitor bank are influenced by load level, generation dispatch, and network topology. A capacitor selected for peak demand conditions may be less effective during off-peak periods. Seasonal variations and network reconfiguration can alter the voltage profile, requiring adaptive compensation strategies.

VIII. FUTURE RESEARCH DIRECTIONS

Optimal Capacitor Placement Using Metaheuristic Algorithms

Future work can determine the best capacitor location and size automatically using optimization techniques such as:

- Genetic Algorithm (GA)
- Particle Swarm Optimization (PSO)
- Differential Evolution (DE)
- Ant Colony Optimization (ACO)
- Grey Wolf Optimizer (GWO)

These methods can simultaneously minimize losses, improve voltage profile, and reduce installation cost.

Integration with On-Load Tap Changers

Combining shunt capacitors with transformer on-load tap changers (OLTCs) can provide more flexible voltage regulation. Coordinated control between discrete capacitor switching and transformer tap movement can enhance system performance under varying load conditions.

Harmonic Analysis and Filter Design

Detailed harmonic studies can be conducted to assess resonance and design tuned or detuned filter banks that provide both reactive power compensation and harmonic mitigation

Renewable Energy Integration

The increasing penetration of solar and wind generation introduces variability and reactive power challenges. Future studies can analyze how capacitor placement interacts with inverter-based resources and distributed generation.

IX. CONCLUSION

This case study presented a detailed investigation of load flow analysis and voltage profile improvement of the IEEE 14-bus power system using shunt capacitor placement. The entire system was modeled and simulated in ETAP, and the Newton-Raphson load flow method was used to determine the steady-state operating condition of the network. The study successfully demonstrated how reactive power compensation can be employed to improve voltage regulation and reduce transmission losses in a practical power system.

The base-case load flow analysis showed that several buses located at the remote end of the network experienced relatively low voltage levels. Among all buses, Bus 14 exhibited the minimum voltage magnitude of 0.961 p.u., making it the weakest bus in the system. This voltage condition indicated a deficiency of local reactive power support and highlighted the need for corrective action to improve the operating margin and strengthen the overall voltage profile.

To address this issue, a 20 MVar shunt capacitor bank was installed at Bus 14. The capacitor supplied reactive power directly at the point of demand, reducing the reactive power burden on generators and minimizing the reactive current flowing through transmission lines. After compensation, the voltage at Bus 14 increased from 0.961 p.u. to 0.983 p.u., representing a significant improvement in the weakest part of the network. Neighboring buses also experienced measurable voltage enhancement, confirming that local reactive support benefits the surrounding electrical area.

REFERENCES

1. R. N. Dhar, Computer Aided Power System Operation and Analysis, Tata McGraw-Hill Publishing Company Ltd., New Delhi, India.
2. M. A. Pai, Computer Techniques in Power System Analysis, Tata McGraw-Hill Education, New Delhi, India.
3. P. Kundur, Power System Stability and Control, McGraw-Hill Education, New York, USA.
4. Hadi Saadat, Power System Analysis, McGraw-Hill Education
5. John J. Grainger and William D. Stevenson Jr., Power System Analysis, McGraw-Hill Education
6. J. Arrillaga and C. P. Arnold, Computer Analysis of Power Systems, Wiley
7. Allen J. Wood, Bruce F. Wollenberg, and Gerald B. Sheblé, Power Generation, Operation, and Control, Wiley
8. A. J. Monticelli, State Estimation in Electric Power Systems: A Generalized Approach, Springer Nature
9. William F. Tinney and Clifford E. Hart, "Power Flow Solution by Newton's Method," IEEE Transactions on Power

Apparatus and Systems, vol. PAS-86, no. 11, pp. 1449–1460, 1967.

10. B. Stott and O. Alsac, “Fast Decoupled Load Flow,” IEEE Transactions on Power Apparatus and Systems, vol. PAS-93, no. 3, pp. 859–869, 1974.

11. Institute of Electrical and Electronics Engineers, “IEEE 14-Bus Test System Data and Standard Power System Test Cases.”

12. Operation Technology, Inc., ETAP User Guide and Technical Document.



INTERNATIONAL
STANDARD
SERIAL
NUMBER
INDIA



INTERNATIONAL JOURNAL OF INNOVATIVE RESEARCH

IN SCIENCE | ENGINEERING | TECHNOLOGY

 9940 572 462  6381 907 438  ijirset@gmail.com



www.ijirset.com

Scan to save the contact details